

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		3		3		3			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		9		9		9			
2	NLG	144	988		1		1		1			
3	MDK	107	933		0		0		0			
4	SDPT				0		0		0			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>14</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 10.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
										Nil		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 10.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Maddur	Renivetla	11KV	Narayanapet	05.30	09.00	03.30		SQUIRREL FALLEN ON THE LINE at RENIVETLA	-
2		Gundumal	Appaipally	11KV	Narayanapet	12.30	14.00	01.30		11KV JUMPER CUT AT BALABADRAIPALLY VG	-
3		Kosgi	Sampally	11KV	Narayanapet	07.00	10.45	03.45		AB Sparking, Sampally vg	-
4		Kosgi	Sampally	11KV	Narayanapet	10.56	12.23	01.27		AB Sparking, Sampally vg Load increase	-
5		Kosgi	Sampally	11KV	Narayanapet	15.33	16.30	00.57		AB Sparking, Sampally vg	-
6		Kosgi	Bhogaram	11KV	Narayanapet	18.46	19.10	00.24		11KV wire cut at Bhogaram vg	-
7		MARIKAL	TILERU	11KV	Narayanapet	03.30	05.25	01.55		11kv line cut at Tileru vlg	-
8		Manthangoud	KATROPALLY	11KV	Narayanapet	07.05	07.20	00.15		squirrel fallen on 11KV line	-
9		Maganoor	WORKUR	11KV	Narayanapet	14.15	15.00	00.45		lorry hit the LT line	-
1	NLG	Nadigudem	Ramapuram	11KV	Huzurnagar	06.40	08.00	01.20	EL	11 KV LINE SNAPPED	-
1	RR N	Mayurinagar	RamnareshnagarCable	11KV	Kukatpally	01.00	02.27	01.27		AB Cable Endkit Failed at Road No:6, Ramnareshnagar	-
1	RR E	Janapriya	Shalivahana	11KV	Habsiguda	02.35	03.40	01.05		Tree fallen on 11Kv line at Yellareddyguda (LM Venkatesh)	-
2		Kusahaiguda	Sri ram Nagar	11KV	Habsiguda	07.10	08.20	01.10		11KV Middle phase Insulator raiser fallen at Gandhi Nagar Bus Stop (AE)	-
3		Chengicherla	My Villas	11KV	Habsiguda	08.25	10.45	02.20		11KV Jumper cut at Chengicherla	-