

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>5</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		2		2		2			
3	MDK	107	933		1		1		1			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>9</b>	<b>0</b>	<b>0</b>	



## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 14.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Vennached	Vennached	11KV	Narayanapet	15.02	16.07	01.05		Disc failure	-
1	NLG	Narketpally	M.Yedavally	11KV	Nalgonda	08.15	09.05	00.50	EL	11KV Jumper cut	-
2		Yararam	Kamepally	11KV	Devarakonda	12.10	12.45	00.35	EL	11 KV Jumper Cutt	-
1	MDK	Gummadidala	Agrobell	11KV	Patancheru	12.57	16.07	03.10		BD Due to Jumper cut	-
1	RR N	Jeedimetla -I	Phase-I	11KV	Jeedimetla	03.15	05.00	01.45	EL/OL	11kv AB cable Failure At Phase-I	-
2		Kolthur	Kolthur	11KV	Medchal	15.10	16.20	01.10	EL	Lizard fallen on the 11KV Line at Potharam Road Kolthur	-
3		Medchal	Navadurga	11KV	Medchal	08.05	08.50	00.45	EL	11KV Pole damaged at Sanitezer Company (11KV Jumper opened)	-
1	HYD S	Khilwath	Lal Darwaza	11KV	III	11.55	13.30	01.35	EL,OL	UG Cable fault at Chowmahalla Palace	(12:48 Hrs partial feeder charged OK)
1	HYD C	Z.P Office	Anand Nagar	11KV	I	17.22	18.30	01.08	EL,OL	Cable fault at Cheman PT, Anand Nagar	-