

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>6</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		3		3		3			
2	NLG	144	988		4		4		4			
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>16</b>	<b>0</b>	<b>16</b>	<b>0</b>	<b>16</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 15.03.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
<b>NIL</b>												

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mohammedabad	Shaikpally	11KV	Narayanapet	10.44	13.00	02.16		11KV Line fallen at Mukkarlabad Village	No
2		Gotoor	Ramkistayapally	11KV	Narayanapet	11.06	11.17	00.11		Insualtor failed	No
3		Hemajipur	Hemajipur	11KV	Jadcherla	04.30	09.50	05.20		11KV Wire cut near Hemajipur	No
1	NLG	Solipet	Solipet	11KV	Bhongir	14:10	15:38	1:28	EL/OL	11KV Insulator Failed near Solipet Village	No
2		Sharajipet	Sharajipet	11KV	Bhongir	08.30	10.00	01.30	EL/OL	100 KVA DTR failed at SS-4 near Sharajipet village.	No
3		Motakondur	Vartoor	11KV	Bhongir	07.15	09.00	01.45	EL/OL	11KV Line snapped near Vartoor village.	No
4		Mandollagudem	Peddakondur	11KV	Choutuppal	09.50	11.04	01.14	EL/OL	11KV Line snapped near Singaraya cheruvu	No
1	SDPT	Bejgama SS	Jaligama	11KV	Gajwel	00:05	08:08	08.03		Conductor snapped	No
2		Singatam SS	Bhacharam	11KV	Gajwel	06.42	09.15	02.33		11KV Insulator failed	No
3		Pamulaparthi SS	Ippalagudem	11KV	Gajwel	07.45	08.45	01.00		Parrot fallen on the 11KV line	No
1	RR N	DP Pally - SS-I	Gandi maisamma	11KV	Jeedimetla	19:52	21:12	1:20	EL/OL	Cat fallen on the D T R & 11kv Jumper cut touched Channel at Gandi maisamma	No
2		Medchal	IDA Kandlakoya	11KV	Medchal	08.00	09.10	01.10	EL	11KV Jumper cut & replaced at Oxygen Park	No
3		Sampanbole	LGM Pet AGL	11KV	Medchal	09.15	12.00	02.45	EL	3 Nos. 11KV Poles damaged by Tipper at Vishwa Company (11KV Jumper opened at Vishwa)	No
4		Thurkapally	Thurkapally	11KV	Medchal	11.00	12.29	01.29	EL	11KV Line AB switch opened at Dharma Reddy Thota (7 Nos. Poles damaged) Single Phase OK	No
1	RR E	CRPF	Chennapur	11KV	Keesara	7:45	9:00	1:15		No visible fault	No
1	HYD C	S.D.Hospital	Ahmed Nagar OH	11KV	VII	19.10	20.37	01.27	EL	Breaker problem at SS	Arranged B/F on 11KV Military fdr