

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	1	0	1	0	1	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		2		2		2			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT				6		6		6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	9	1	9	1	9	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 16.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Kandi	Sangareddy -I	33KV	Sangareddy	09.30	10.40	01.10		B/D due to Conductor snapped	Sangareddy -I	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Mukundapuram	Dacharam	11KV	Huzurnagar	04.00	07.45	03.45	EL	11KV Line Snapped	-
2		Nandanam	Anajipur	11KV	Bhongiri	06.45	09.10	02.25	EL	11 kv Line snapped near Anajipur village.	-
1	MDK	Sangareddy Rural	P.R.Pally	11KV	Sangareddy	08.31	09.44	01.13		B/D due to Bird fallen on the line	-
1	SDPT	Pothareddypet	Pothareddypet	11KV	SIDDIPET	11.10	12.20	01.10		B/D 11kv jumper cut Ic no. 15821	-
2		Pothareddypet	Thallapally	11KV	SIDDIPET	14.42	18.29	03.47		B/D 11kv disk fail Ic no.15822	-
3		Gambeerpur	Gambeerpur	11KV	SIDDIPET	07.15	07.35	00.20		B/D due to line problem	-
4		Gurjakunta	Dommata	11KV	HUSNABAD	04.48	00.00	09.36		BD due to line cut and pole damaged	-
5		Pamulaparthi SS	Express	11KV	GAJWEL	13.50	14.40	00.50		CTPT fail in Express Com.	-
6		Mulugu SS	Narsampally	11KV	GAJWEL	13.47	15.58	02.11		Snake Fallen And Insulator Fail	-
1	HYD C	Fever Hospital	Tourist Hotel	11KV	II	17.30	18.50	01.20	All Indicatoin	RMU fault at Ratna Deep Super Market	