

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	2	1	2	1	2			
7	RR(E)	168	403									
8	Hyd	194	1044		4		4		4			
	Total	606	3055	1	6	1	6	1	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		1		1		1			
3	MDK	107	933		2		2		2			
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	4	0	4	0	4	0	0	
	Grand Total	1082	6468	1	10	1	10	1	10	0	0	

TSSPDCL - LMRC / Corporate office

Date: 19.03.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	RR N	132KV LGM Pet	Aliabad	33KV	Medchal	13:05	16:52	3:47		33KV Jumper Cut & Replaced at LGM Pet	Aliabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Eklaspur	Chittanur	11KV	Narayanapet	09.50	10.20	00.30		No visible fault	No
1	NLG	B.Chandupatla	Chandupatla	11KV	Suryapet	9:10	10:40	1:30	E/L	Jumper cut	No
1	MDK	EPIP-I	Biocon	11KV	Sangareddy	11:30	12:20	0:50		Conductor Snapped	No
2		Dundigal	Annaram	11KV	Patancheru	16.45	19.40	02.55		Jumper Cut	No
1	RR N	Jagathgirigutta	Shiridihills	11KV	Medchal	19:35	20:25	0:50	BD	11KV Cable Endkit failed at RGK Block 4	No
2		Vijayanagar	ASR Rajunagar	11KV	Kukatpally	17.20	18.30	01.10	EL/OL	Tree branchesh fallen the 11kv T/F at Patel kuntta Park	No
1	HYD N	Seethaphal Mandi	Warasiguda	11KV	V	11.25	12.43	01.18	EL	No Visible Fault	Arranged B/F on 11KV Boudha Nagar feeder
2		Clock Tower	Natraj	11KV	V	11:55	13:28	1:33	All Indication	Jumper cut near SS	No
1	HYD S	Kandikal Gate	G.M Chowni	11KV	III	18.30	19.37	01.07	EL	No Visible Fault	Arranged B/F on 11KV Chatrinaka fdr
2		Malakpet	Farhath Nagar	11KV	VIII	21:30	23:25	1:55	All Indication	End Kit failed at Farhath Nagar Nala	Arranged B/F on 11KV Azampura fdr