

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403									
8	Hyd	194	1044		0		0		0			
	Total	606	3055	0	0	0	0	0	0	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		2		2		2			
2	NLG	144	988		2		2		2			
3	MDK	107	933		1		1		1			
4	SDPT				2		2		2			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	0	7	0	7	0	7	0	0	
	Grand Total	1082	6468	0	7	0	7	0	7	0	0	

TSSPDCL - LMRC / Corporate office

Date: 22.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR				NIL							-
2	NLG				NIL							-
3	MDK				NIL							-
4	SDPT				NIL							-
5	RR S				NIL							-
6	RR N				NIL							-
7	RR E				NIL							-
8	HYD				NIL							-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 22.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	MOGALMADKA	ANNASAGAR	11KV	Narayanapet	11.10	13.10	02.00		11KV cond cut at gathpa vlg	-
2		Bijwar	BIJWAR	11KV	Narayanapet	06.50	07.20	00.30		Reptile fallen on 11Kv line	-
1	NLG	Thatipamula	Thatipamula	11KV	Suryapet	05.00	08.20	03.20	EL	Jumper cut	-
2		Ananthram	Ananthram	11KV	Bhongir	15.08	16.48	01.40	EL/OL	11KV Line snapped near Tajpur Village	-
1	MDK	Athmakur	Manjith	11KV	Sangareddy	18.20	21.10	02.50		B/D due to Tree branches fallen on the line	-
1	SDPT	Ankshapur	Nagarajupally	11KV	Siddipet	06.45	10.30	03.45		BD, LT/ HT	-
2		Nagapuri	Pothireddypally	11KV	Husnabad	13.35	16.55	03.20		BD, LT/ HT	-