

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988		3		3		3			
3	MDK	107	933		1		1		1			
4	SDPT			1		1		1				
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	6	3	6	3	6	0	0	
	Grand Total	1082	6468	3	8	3	8	3	8	0	0	

TSSPDCL - LMRC / Corporate office

Date: 23.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Balanagar	Amit Cotton Mill	33KV	Jadcherla	13.40	15.55	02.15		Post off Insulator Damaged at Petrol Pump Balangar	Amit Cotton Mill	-
2		Balanagar	Nava Durga	33KV	Jadcherla	14.15	15.55	01.40		Post off Insulator Damaged at Petrol Pump Balangar	Nava Durga	-
1	SDP	Habsipur	Kajipur	33KV	Siddipet	15.30	16.55	01.25		BD (tree cutting)	Kajipur	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 23.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Mogalmadka	Mogalmadka (T)	11KV	Narayanapet	11.01	11.25	00.24		Squirrel fallen on 11kv line at Mogalmadka town	-
2		Kolpur	Kolpur	11KV	Narayanapet	07.55	10.10	02.15		Tree branch fallen on 11KV line at Paramondoodi vlg	-
1	NLG	Reddygudem	Kothagudem	11KV	Suryapet	11.30	13.24	01.54	E/L	Insulator failed	-
2		Akupamula	K K Gudem	11KV	Huzurnagar	06.15	08.00	01.45	E/L	11 KV LINE SNAPPED	-
3		Solipet	Ramuluthanda	11KV	Bhongir	04.20	08.00	03.40	E/L	11 kv Line snapped near Ramuluthanda village	-
1	MDK	EPIP-III	Tyechi Diecast Feeder	11KV	Sangareddy	12.50	14.30	01.40		B/D Due to Lorry broken to 11KV Pole	-
1	RR E	P&T colony	Canara nagar	11KV	Keesara	07.05	08.40	01.35		AB switch open due to 11kv line touch iron Pole at medipally	-
1	HYD N	Macha Bollaram	Ayyappa Nagar	11KV	C-VI	11.55	13.46	01.51	AR tripped	Pole damaged at Kaveri Enclave	Partial feeder charged & remaining loads added on 11KV HMT Officers Colony feeder