

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	2	1	2	1	2			
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>2</b>	<b>7</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>2</b>	<b>10</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 25.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Pebbair	33KV	Wanaparthi	13.30	15.08	01.38	O/L	No Visible Fault		-
1	MDK	Sadasivpet	Koheer	33KV	Sangareddy	08.20	19.05	10.45		BD due to Pin Binding failed and alternate supply arranged from 132KV SS		-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 25.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Ravulapally	Manapuram	11KV	Suryapet	10.30	12.00	01.30	EL	Jumpur cut	-
1	MDK	EPIP-II	Marigold	11KV	Sangareddy	03.00	07.45	04.45		BD due to Conductor snapped	-
2		Anrich Bollaram	Town-II	11KV	Patancheru	14.20	17.00	02.40		BD due to Cable kit failed	-
3	SDPT	PAMULAPARTHY	33/11 KVA SHUTDOWN (LC NO: 14119/ CHANDRAM. CL	11KV	Gajwel	16.15	18.45	02.30		BUSBAR & AB SWITCH WORK	-
4		GOWRARAM	GOWRARAM AGL (LC NO: 11414/ SRIDHER. CL	11KV	Gajwel	13.30	15.35	02.05		11KVA INSULATOR FAILED	-
5		BEJJANKI	REGULAPALLY	11KV	Husnabad	11.25	12.40	01.15		INSULATOR FAILURE	-
6		Gagillapur	Gagillapur Agl	11KV	Husnabad	08.52	13.29	04.37		TREE FALL & JUMPER CUT	-
1	RR N	Subhash Nagar	Suchitra	11KV	Medchal	02.40	03.10	00.30		11KV Line cut and replaced at Teja Wines Backside	-
1	RR E	IDA Uppal	Ferrocast	11KV	Habsiguda	14.55	15.45	00.50		Line Patrolling but no visible fault	-
1	HYD N	Gunrock	Tirumalagiri	11KV	Bowenpally	23.55	01.06	01.11	EL,OL	No Visible Fault	Arranged B/F on 11KV Srinagar Colony for