

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403									
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	2	0	2	0	2	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2		2		2				
2	NLG	144	988	1		1		1				
3	MDK	107	933									
4	SDPT				3		3		3			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	3	3	3	3	3	0	0	
	Grand Total	1082	6468	3	5	3	5	3	5	0	0	

TSSPDCL - LMRC / Corporate office

Date: 29.03.2021

Circle-wise 33KV Breakdowns

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Nawabpet	33KV	Mahabubnagar	09.06	12.18	03.12	EL	Conductor Snapped & Insulators Replaced at Timmasanipally		-
2		Polepally	Polepally	33KV	Jadcherla	09.02	12.55	03.53	EL	Phase to Phase at Polepally SEZ		-
1	NLG	Aitipamula	Kethepally	33KV	Nalgonda	10.40	14.45	04.05	E/L	33Kv Conductor snapped at near 132KV Aitipamula SS		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 29.03.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	SDPT	Thimmapur	Thimmapur	11KV	Siddipet	06.52	07.15	00.23		B/D- 24 Kv Dtr Failure	-
2		Ganeshpally SS	Ganeshpally Town LC: 25501 suresh CL	11KV	Gajwel	10.40	11.00	00.20		Insulator fail	-
3		Thunki bollaram SS	Achaiapally LC: 36696 Ramulu JLM	11KV	Gajwel	07.00	11.10	04.10		11 KV Line cut	-
1	RR N	Prashanth Hills	Prashanth Hills	11KV	Kukatpally	19.43	20.53	01.10	OL	AB Cable Failed at Madhuranagar, Phase-I	-
1	HYD C	Amberpet	C.P.L.	11KV	Azamabad	15.47	18.43	02.56	EL	Pin Insulator flash over at CPL Quarters	Arranged B/F on 11KV Prem Nagar feeder