

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		3		3		3			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	6	0	6	0	6	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		5		5		5			
2	NLG	144	988		3		3		3			
3	MDK	107	933	3		3		3				
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	3	12	3	12	3	12	0	0	
	Grand Total	1082	6468	3	18	3	18	3	18	0	0	

TSSPDCL - LMRC / Corporate office

Date: 31.03.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Pashamailaram	BPL	33KV	Sangareddy	11:00	13:00	2:00		Jumper cut	BPL	No
2		Zaheerabad	Hadnoor	33KV	Zaheerabad	12.10	14.20	02.10		Jumper cut	Hadnoor	No
3		Zaheerabad	Chota Hyderabad	33KV	Zaheerabad	21.10	22.55	01.45		Insulator Faliure	Chota Hyderabad	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	KANUKURTHY	LOKURTHY	11KV	NARAYANPET	06.40	09.56	03.16		Due to 1/3RD phase at Lokurthy vlg	No
2		EKLASPUR	KANMANUR	11KV	NARAYANPET	13.10	14.10	01.00		Due to 11kv line fallen at Kanmanoor vlg	No
3		MOGALMADKA	MOGALMADKA RURAL	11KV	NARAYANPET	07.20	08.20	01.00		Due to DTR fault at Mogalmadka rural	No
4		MOGALMADKA	MOGALMADKA(T)	11KV	NARAYANPET	14:28	16:30	2:02		Due to tree cutting at Mogalmadka town	No
5		MARIKAL	ELIGANDLA	11KV	NARAYANPET	16.24	18.02	01.38		Due to HT/LT at Paspula vlg	No
1	NLG	YACHARAM	YACHARAM	11KV	Miryalaguda	14:12	17:15	3:03	EL	Tree branches fallen on 11KV line near Yacharam village	No
2		Kudakuda	M.G Nagar thanda	11KV	Suryapet	07.07	08.10	01.03	EL	Insulator failed	No
3		Mukundapuram	Kalluru	11KV	Huzurnagar	07.45	09.00	01.15	EL	11 KV Line snapped	No
1	SDPT	Maddur	Maddur AGL	11KV	Husnabad	3:25	8:40	5:15		Jumper Cut	No
2		Gagillapur	Gagillapur Town	11KV	Husnabad	14.37	15.30	00.53		Monkey Fallen on the Line	No
3		Potharam	Vangaramayyapally	11KV	Husnabad	11.45	12.25	00.40		Insulator Fail	No
4		Nangnoor	Nagarajpally	11KV	Siddipet	06.42	08.40	01.58		11 KV Wire stringing	No
1	RR N	Aliabad	HBL	11KV	Medchal	13:00	13:50	0:50		LV-II Bus bar snapped at SS	No
2		Uddamarry	Usharpally	11KV	Medchal	13.48	15.00	01.12		Neutral wire Touched on the 11KV Line at Church Colony	No
3		Jeedimetla-II	Phase-IV	11KV	Jeedimetla	12.00	14.00	02.00		11KV Pin insulator failed & replaced at MC Pally Road	No
1	RR E	Mallapur-2	Surya Nagar	11KV	Habsiguda	7:18	7:58	0:40		100KVA T/F Jumper cut at Surya Nagar Community Hall	No
2		Chengicherla	My Villas	11KV	Keesara	15.30	17.00	01.30		11KV Copper patti cut at Reliance Tower	No
1	HYD C	Fever Hospital	Fever Hospital	11KV	II	23.45	01.24	01.39	EL	Cable fault Opp SBI, Barkathpura Chaman	2 Nos DTR kept off

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
------	--------	-----------------------	-------------------------	-----	-------------------------	------	----	----------	---------------------	--------------------	---------------------------