

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		4		4		4			
7	RR(E)	168	403		2		2		2			
8	Hyd	194	1044		48		48		48			
	Total	606	3055	0	54	0	54	0	54	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	4	1	4	1	4	1			
2	NLG	144	988		1		1		1			
3	MDK	107	933	1	6	1	6	1	6			
4	SDPT			1	11	1	11	1	11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	19	6	19	6	19	0	0	
	Grand Total	1082	6468	6	73	6	73	6	73	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 03.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Ghanpur	33KV	Mahabubnagar	15.50	16.00	00.10	O/L	Under Ground Cable Fault at vidyuth bhavan M.Nagar	Ghanpur	-
2		Mahabubnagar	Machanpally	33KV	Mahabubnagar	19.00	19.10	00.10	E/L	Due to Rain	Machanpally	-
3		Narayanapet	Narayanapet-2	33KV	Narayanapet	17.10	17.15	00.05	E/L	Due to Rain	Narayanapet-2	-
4		Narayanapet	Maddur	33KV	Kankurthy	21.07	21.10	00.03	E/L	Due to Heavy Gale&Rain	Maddur	-
1	MDK	R.C.Puram	TSIIC	33KV	Patancheru	15.35	19.05	03.30		B/D due to Insulator failed	TSIIC	-
2	SDPT	Habsipoor	Pothareddypet	33KV	SDPT	16.50	18.25	01.35		B/D Lizard Fall Down	Pothareddypet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 03.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Hanwada	Buddaram	11KV	Mahabubnagar	17.23	18.45	01.22		11KV Phase to Phase Near Hanwada AGL	-
1	NLG	Chamapur	Singaram	11KV	Bhongiri	09.40	13.30	03.50	EL	100 KVA Dtr failed near Kalwapally village	-
1	MDK	Sangareddy Town-II	Filterbed	11KV	Sangareddy	10.30	12.15	01.45		B/D Due to Jumper Cut & Tree branches fallen on the line	-
2		Sangareddy Town-II	Kosla	11KV	Sangareddy	15.45	18.10	02.25		B/D due to Tree branches fallen on the line & Conductor snapped	-
3		Bollaram-II	Rupa	11KV	Patancheru	15.24	18.53	03.29		B/D due to Conductor snapped	-
4		Patancheru Town	MIA-I	11KV	Patancheru	15.15	16.35	01.20		B/D due to Tree branches fallen on the line	-
5		Patancheru Town	MIA-I	11KV	Patancheru	17.05	19.15	02.10		B/D due to Insulator failed	-
6		Patancheru Town	Town	11KV	Patancheru	15.15	16.55	01.40		B/D due to Tree branches fallen on the line	-
1	SDPT	Mittapally	Yellupally	11KV	Siddipet	17.30	18.00	00.30		B/D Tree Buch Fall Down Lc 2235	-
2		Raghavapur	Peddalingareddypally	11KV	Siddipet	18.47	19.20	00.33		B/D 11 kv Line Cut IC 19012	
3		Ramancha	Gangapoor	11KV	Siddipet	17.10	18.00	00.50		B/D Face To Face Lc-20253	
4		Chellapur	Chellapur	11KV	Siddipet	04.19	06.00	01.41		B/D Insulator Fail Lc 16514	
5		Chellapur	Godugumarri	11KV	Siddipet	04.19	06.00	01.41		B/D 11kv Dtr Touch Lc No 16515	
6		WARGAL SS	WARGAL AGL	11KV	Gajwel	17.45	18.40	00.55		11KV PIN INSULATOR FAILED	
7		THUNKIBOLLARAM	THUNKIBOLLARAM	11KV	Gajwel	02.30	10.30	08.00		11KV LINE CUT,AND PHASE TO PHASE	
8		MASANPALLY SS	MASANPALLY FEEDER	11KV	Gajwel	16.30	17.07	00.37		TREE BRANCH FALLEN	
9		RAIPOLE SS	THIMMAKKAPALLY	11KV	Gajwel	17.02	17.22	00.20		11KV LINE PHASE TO PHASE	
10		BEGAMPET SS	BEGAMPET FEEDER	11KV	Gajwel	17.50	19.02	01.12		INSULOTAR FAILED	
11		Husnabad-II	Malapally	11KV	Husnabad	14.15	16.45	02.30		Squirrel fallen on the line	
1	RR N	Yellampet	IDA Yellampet	11KV	Medchal	15.07	15.57	00.50		Tree Branch fallen on the 11KV line at Sangam Company	-
2		Kistapur	IDA Hanuman	11KV	Medchal	17.50	18.23	00.33		11KV Pin Insulator failed at Paragon Biscuit Company	-
3		Athiwelly	Dabeerpur	11KV	Medchal	15.50	17.40	01.50		Bird fallen on the 11KV Line at Dabeerpur Cheruvu	-
4		Jeedimetla-IV	Axies	11KV	Jeedimetla	15.45	17.40	01.55		11kv AB cable failure At A line company	-
1	RR E	Uppal	Raghavendra Colony	11KV	Habsiguda	16.20	17.05	00.45		Tree branches fallen on 11KV line at Raghavendra Colony Community Hall	-
2		Uppal	Adarsha Nagar	11KV	Habsiguda	16.21	17.30	01.09		HT/LT lines touched & 11KV Brass patti cut at Seven Hills Colony	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD N	Road No.22	Jubilee Hills PS	11KV	X	15:52	18:02	2:10	EL,OL-Rph	Tree branches fallen on lines at Road No.17	-
2		Prashasan Nagar	Journalist Colony	11KV	X	15:54	17:54	2:00	EL,OL	Tree branches fallen on lines at Journalist Colony	-
3		Film Nagar	B.V.Bhavan	11KV	X	15:56	17:50	1:54	OL	Tree branches fallen on lines at B.V.Bhavan School	-
4		Prashasan Nagar	Seri Culture	11KV	X	15:58	17:23	1:25	EL,OL	Tree branches fallen on lines at Seri Culture	-
5		Film Nagar	Ambedkar Colony	11KV	X	16:04	18:56	2:52	EL,OL,	Tree branches fallen on lines at Film Chamber	-
6		Chilkaiguda	Pragatools	11KV	V	16:05	17:15	1:10	OL-Rph	No Visible Fault (Due to Rain & Gale)	-
7		Chinna Thokatta	Dubai Gate	11KV	VI	16:08	17:30	1:22	EL	Jumper cut at Opp. SS	-
8		I.D.P.L.	Shivalayam	11KV	VI	16:10	17:30	1:20	EL	Tree branches fallen on lines at Railway Track	-
9		Road No.13	Sri Ram Nagar	11KV	X	16:10	17:40	1:30	EL,OL	No Visible Fault (Due to Rain & Gale)	-
10		Jubilee Hills	P.E.I. OH	11KV	X	16:15	18:35	2:20	All Indication	No Visible Fault (Due to Rain & Gale)	-
11		Road No.13	G.S.Nagar	11KV	X	16:16	17:20	1:04	EL,OL	No Visible Fault (Due to Rain & Gale)	-
12		Jubilee Hills	H.P.Gas	11KV	X	16:20	18:10	1:50	All Indication	Tree branches fallen on lines at Road No.48	-
13		Road No.13	Sai Enclave	11KV	X	16:20	17:35	1:15	EL	No Visible Fault (Due to Rain & Gale)	-
14		Jubilee Hills	B.S.N.L.	11KV	X	16:27	17:40	1:13	EL,OL,	Tree branches fallen on lines at BSNL	-
1	HYD S	Miralam	Hasan Nagar	11KV	III	15:55	18:40	2:45	EL	Burntout 3No. HG fuses & 2No. Brass Patties at Anthony School	-
2		Miralam	Ameena Masjid	11KV	III	16:01	17:10	1:09	EL,OL	No Visible Fault (Due to Rain & Gale)	-
3		Seetharambagh	Kishan Nagar	11KV	IX	16:05	18:00	1:55	EL,OL	No Visible Fault (Due to Rain & Gale)	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Hyd C	Golconda	Narayana College	11KV	VII	15:45	18:00	2:15	EL,OL-Bph	Tree branches fallen on lines at Darga	-
2		Golconda	O.U.Colony	11KV	VII	15:45	17:50	2:05	EL,OL	No visible Fault (Due to Rain & Gale)	-
3		Golconda	Darga Cable	11KV	VII	15:45	17:30	1:45	EL,OL-R&Yph	DTR fault at D-Mart	-
4		Nampally	Nampally Hospital	11KV	VII	15:48	17:55	2:07	EL	Tree branches fallen on lines at Nampally Hospital	-
5		Gudimalkapur	Sri Ram Nagar	11KV	VII	15:48	20:20	4:32	EL,OL	Tree branches fallen on lines at Geethanjali Enclave	-
6		Gudimalkapur	Murad Nagar	11KV	VII	15:49	19:33	3:44	EL	Tree branches fallen on lines at Murad Nagar	-
7		Asif Nagar	Kakatiya Nagar	11KV	VII	15:49	18:05	2:16	All Indication	Tree branches fallen on lines at ICICI Bank & Military Hospital	-
8		ITI Mallepally	Zaheera Masjid	11KV	VII	15:49	17:49	2:00	EL	Tree branches fallen on lines at Mallepally	-
9		ITI Mallepally	Iiyas Road	11KV	VII	15:50	18:50	3:00	EL	Tree branches fallen on lines at Police Quarters	-
10		A.C.Guards	Mahaveer OH	11KV	I	15:50	18:00	2:10	EL,OL-R&Bph	No Visible Fault (Due to Rain & Gale)	-
11		Z.P.Office	H.P.Sabha	11KV	I	15:50	18:17	2:27	EL	Tree branches fallen on lines at Lotus Hospital	-
12		Asif Nagar	Hakimpet	11KV	VII	15:50	18:30	2:40	EL	Tree branches fallen on lines at Alasnath Colony	-
13		Gudimalkapur	Navodaya Colony	11KV	VII	15:51	18:35	2:44	EL,OL-Rph	Tree branches fallen on lines at Navodaya Colony	-
14		A.S.R.Raju Nagar	Golla Basthi	11KV	VII	15:51	18:00	2:09	EL,OL	No visible Fault (Due to Rain & Gale)	-
15		Gudimalkapur	Sharada Nagar	11KV	VII	15:54	17:46	1:52	EL	No visible Fault (Due to Rain & Gale)	-
16		Z.P.Office	Anand Nagar	11KV	I	15:54	18:58	3:04	EL,OL	Faulty 1No.DTR at Anand Nagar	-
17		Asif Nagar	Mehdapatnam OH	11KV	VII	15:55	17:38	1:43	EL	No visible Fault (Due to Rain & Gale)	-
18		Asif Nagar	Military	11KV	VII	15:55	17:28	1:33	EL	No visible Fault (Due to Rain & Gale)	-
19		A.S.R.Raju Nagar	Ushodaya Colony	11KV	VII	15:55	17:20	1:25	EL,OL	No visible Fault (Due to Rain & Gale)	-
20		A.S.R.Raju Nagar	A.S.R.Raju Nagar	11KV	VII	15:55	18:27	2:32	EL,OL	No visible Fault (Due to Rain & Gale)	-
21		A.S.R.Raju Nagar	J.K.Nagar	11KV	VII	15:56	17:18	1:22	EL	No visible Fault (Due to Rain & Gale)	-
22		Asif Nagar	Padmanabha Nagar	11KV	VII	15:56	18:40	2:44	EL	Tree branches fallen on lines at 777 Hotel	-
23		Langer House	Fathe Darwaza	11KV	VII	15:58	17:28	1:30	All Indication	Tree branches fallen on lines at HUDA Park	-
24		Gudimalkapur	Amba Garden	11KV	VII	16:00	17:21	1:21	OL-R&Yph	No visible Fault (Due to Rain & Gale)	-
25		Asif Nagar	NSF Colony	11KV	VII	16:01	17:38	1:37	EL	No visible Fault (Due to Rain & Gale)	-
26		Mothi Mahal	Balancer	11KV	VII	16:02	17:14	1:12	EL	UG Cable fault near Golconda Fort	-
27		Langer House	Defence Colony	11KV	VII	16:04	17:53	1:49	All Indication	Tree branches fallen on lines at Defence Colony	-
28		A.C.Guards	N.M.D.C.	11KV	VII	16:16	17:55	1:39	OL-R&Bph	No visible Fault (Due to Rain & Gale)	-
29		Z.P.Office	Ramleela Maidan	11KV	I	16:37	17:58	1:21	OL	No visible Fault (Due to Rain & Gale)	-
30		Asif Nagar	Avalon	11KV	VII	16:43	18:10	1:27	EL	Faulty 11KV Padmanabha Nagar feeder loads	-
31		Toli Chowki	Ameena Masjid	11KV	VII	17:00	19:15	2:15	EL	AB Cable fault at Toli Chowki	-