

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		18		18		18			
	Total	606	3055	0	20	0	20	0	20	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	5	8	5	8	5	8			
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT				4		4		4			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	5	14	5	14	5	14	0	0	
	Grand Total	1082	6468	5	34	5	34	5	34	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 04.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	220/132KV SS Palkonda	Janampet	33KV	Mahabubnagar	16.43	17.13	00.30	E/L	Due to Rain		NO
2		Wanaparthi	Solipur-2	33KV	Wanaparthi	18.42	20.20	01.38	E/L	Due to Rain		Alternate supply Arranged From 33KV Solipur From 132KV SS Ghanapur at 20:20Hrs
3		Wanaparthi	Revally	33KV	Wanaparthi	18.45	19.30	00.45	E/L	Due to Rain		Alternate supply arranged From 33KV Peddakothapilly from 19:30 Hrs
4		Wanaparthi	Pebbair	33KV	Wanaparthi	18.42	20.30	01.48	E/L	Due to Rain		Alternate supply arranged From Williamkonda at 20:30Hrs.
5		Wanaparthi	Buddaram	33KV	Wanaparthi	18.43	21.02	02.19	E/L	Due to Rain		Alternate Supply Arranged From Gopalpet at 21:02

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 04.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	MARIKAL	P.C.KUNTA	11KV	Narayanapet	09.01	12.06	03.05		Phase to phase at P.C.Kunta(V)	-
2		KYATHANPALLY	WATTUGUNDLA	11KV	Narayanapet	06.24	09.05	02.41		Tree branch fallen on 11KV line at Kamsanpally vlg	-
3		NARAYANPET	Naryanpet Town (CIVIL)	11KV	Narayanapet	13.55	16.00	02.05		Pin Binding cut and fallen on DTR at Damargidda Road	-
4		Kosgi	Kosgi	11KV	Narayanapet	17.00	17.50	00.50		Tree Branch Fallen on 11KV line at Nacharam(V)	-
5		Kosgi	Sampalli	11KV	Narayanapet	17.00	17.30	00.30		Phase to phase trip at sampalli(V)	-
6		Kosgi	Musriffa (Vittalapur)	11KV	Narayanapet	17.00	18.30	01.30		Cloth Fallen on 11KV line at Gundumal(V)	-
7		PALLERLA	Parsapur	11KV	Narayanapet	21.00	10.00	13.00		AB switch fallen on DTR at parsapur(V)	-
8		Karkonda	Karkonda	11KV	Jadcherla	09.57	12.23	02.26		11 KV Line cut Near Shanagadda Thanda	-
1	NLG	Velugupally	Aithavarigudem	11KV	Nalgonda	05.35	07.00	01.25	E/L	11Kv Jumper cut	-
2		Velugupally	Keshavapuram	11KV	Suryapet	04.30	07.00	02.30	E/L	11Kv Conductor snapped	-
1	SDPT	Raghavapur	Peddalingareddypally	11KV	Siddipet	00.00	07.30	07.30		B/D-Tree bunches fallen on line-Rectified	-
2		GOVINDAPUR SS	GOVINDAPUR FEEDER	11KV	Gajwel	18.00	19.00	01.00		KONAPUR VILLAGE SIDE JUMPER OUT	-
3		Guruvannapet	Tapaspally	11KV	Husnabd	07.05	07.30	00.25		TREE FALL	-
4		Guruvannapet	Tapaspally	11KV	Husnabd	17.03	19.35	02.32		BREAK DOWN 1-PH OK	-
1	RR N	Kandlakoya	Saigeetha Ashramam	11KV	Medchal	12.12	13.10	00.58	BD	Tree Branch fallen on the 11KV line at Chaitya Techno School	-
2		Devarayamjal	Mandaipally	11KV	Medchal	12.45	13.40	00.55	BD	25KVA DTR failed at Yellamma Temple, Mandaipally	-
1	HYD N	Alwal	Dinakar Nagar	11KV	C-VI	12.45	15.00	02.15	OL-Rph	Tree branches fallen on lines at Dinakar Nagar	-
2		Chilalguda	Dandu Pentaiah	11KV	V	13.24	15.03	01.39	EL,OL-Rph	Tree branches fallen on lines at NTR Statue	-
3		Chilalguda	P.R.Nagar	11KV	V	13.25	15.45	02.20	EL,OL-Rph	HT Jumper cut at Shivananda Asramam	-
1	HYD S	Malakpet	Farath Nagar	11KV	VIII	13.25	15.30	02.05	EL,OL-Rph	Tree branches fallen on lines at T.B.Hospital	-
2		Chanchalguda	Chanchalguda	11KV	VIII	13.30	15.40	02.10	EL,OL-Rph	Tree branches fallen on lines at Chanchalguda	Arranged B/F on 11KV P&T Colony fdr
3		Malakpet B-Block	L.I.C Colony	11KV	VIII	13.33	15.36	02.03	OL-Rph	Jumpers cut at LIC Colony	Arranged B/F on 11KV Quthbiguda fdr
4		Asmangadh	Shiva Ganga	11KV	VIII	13.36	15.00	01.24	EL	No Visible Fault (Due to Rain)	-
5		E.N.T	E.N.T	11KV	IX	13.38	15.04	01.26	EL,OL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Osmanpura fdr
6		Yakuthpura	Khan Nagar	11KV	VIII	13.50	15.30	01.40	OL-Rph	Jumper cut at Nizam Hotel	-
7		Malakpet	M.M.H	11KV	VIII	16.56	18.18	01.22	All Indication	AB Switch fault at Cable raising point	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	HYD C	Chilkaiguda	Parsigutta	11KV	II	13.20	15.10	01.50	EL	No Visible Fault (Due to Rain)	-
2		Industrial Area	Barkathpura	11KV	II	13.20	14.50	01.30	All Indication	Tree branches fallen on lines at Nallakunta Market	-
3		Industrial Area	Shankarmutt	11KV	II	13.20	15.15	01.55	All Indication	No Visible Fault (Due to Rain)	-
4		Narayanguda	Preventive Medicine	11KV	II	13.20	14.50	01.30	EL	No Visible Fault (Due to Rain)	-
5		Chilkaiguda	Golconda X Road	11KV	II	13.22	14.40	01.18	EL	No Visible Fault (Due to Rain)	-
6		Jawahar Nagar	Post Office	11KV	I	13.30	14.55	01.25	EL	No Visible Fault (Due to Rain)	Arranged B/F on 11KV Balaji Indra Prasta fdr
7		Jawahar Nagar	Jawahar Nagar	11KV	I	13.32	14.45	01.13	EL	Tree branches fallen on lines	-
8		Bathakamma Kunta	Ayyappa Temple	11KV	II	13.33	15.20	01.47	EL	Pin Insulator flash over at Mallikarjuna Nagar	-