

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550									
7	RR(E)	168	403		5		5		5			
8	Hyd	194	1044									
	Total	606	3055	0	5	0	5	0	5	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1		1		1				
2	NLG	144	988		2		2		2			
3	MDK	107	933									
4	SDPT											
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	1	2	1	2	1	2	0	0	
	Grand Total	1082	6468	1	7	1	7	1	7	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 08.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Makthal	Utkoor	33KV	Mahabubnagar	03.30	03.40	00.10	EL	Conductor Snapped at Madwar Village	-	Alternate Supply Arranged From 132KV Narayanpet at 3:40Hrs

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 08.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Aipoor	Kotapahad	11KV	Suryapet	07.20	09.20	02.00	EL	Conductor snapped	-
2		Akupamula	Kodadndarapuram	11KV	Huzurnagar	03.45	07.15	03.30	EL	11 KV LINE SNAPPED	-
1	RR E	Boduppall	Ayyappa nagar	11KV	Habsiguda	23.50	00.20	00.30		Tree branches fallen on 11kv line at East balaji Hills	-
2		Sai nagar	RNS colony	11KV	Habsiguda	04.00	04.55	00.55		11KV Cable cut at RNS colony	-
3		Kushaiguda	Kapara	11KV	Sainikpuri	12.55	15.05	02.10		11KV Cable failure at Road No 1 Bahavani Nagar (AE)	-
4		Aushapur	Aushapur	11KV	Keesara	10.34	11.30	00.56		Line petroing donebut no visiable falt found	-
5		Narapally	P.singaram	11KV	Keesara	12.02	12.55	00.53		Lorry dashed at 11KV Pole at venkatapur	-