

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403									
8	Hyd	194	1044		2		2		2			
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		1		1		1			
3	MDK	107	933		1		1		1			
4	SDPT			2	13	2	13	2	13			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	2	16	2	16	2	16	0	0	
	Grand Total	1082	6468	2	20	2	20	2	20	0	0	

TSSPDCL - LMRC / Corporate office

Date: 10.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDPT	Husnabad	Dharmaram	33KV		16:35	19:50	3:15		Jumper cut	Dharmaram	No
2		Mustyala	Doolmitta	33KV		06.50	09.30	02.40		Tree fallen on the line	Doolmitta	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	SARJAKANPET	HAKEEMPET	11KV	NARAYANPET	13.15	15.16	02.01		Tree branch fallen on the 11kv line at Hakeempet vlg	No
1	NLG	Ravulapally	Manapuram	11KV	Suryapet	5:30	7:00	1:30	EL	Jumper cut	No
1	MDK	Inole	Peddakanjarla	11KV	Sangareddy	8:30	10:30	2:00		B/D Due to tree branch fallen on the line	No
1	SDPT	Thornal	Appanapally	11KV	Siddipet	11:13	12:54	1:41		B/D AB Switch problem	No
2		THIGUL	THIGUL AGL	11KV	Gajwel	10:32	13:01	02:29		11KV LINE CUT	No
3		JAGADEVPUR	ITIKYAL	11KV	Gajwel	14:28	15:28	01:00		11KV LINE CUT	No
4		JAGADEVPUR	JAGADEVPUR TOWN	11KV	Gajwel	16.20	17.20	01.00		TREE BRANCH FALL OVER 11 KV	No
5		MULUGU	MULUGU AGL	11KV	Gajwel	10.45	11.10	00.25		11KV JUMPER CUT	No
6		MEDINIPUR	KUKUNOOR PALLY TOWN	11KV	Gajwel	17.35	21.10	03.35		JUMPER CUT	No
7		GURRALASOPA	VADDEPALLY	11KV	Gajwel	15:35	16:45	01:10		111KV POLE DAMAGED	No
8		Husnabad	Town I	11KV		16.50	17.25	00.35		Gale and Wind	No
9		Husnabad New	Malapally	11KV		16.45	19.40	02.55		Poles damaged	No
10		Potharam	Nagaram	11KV		17.50	18.25	00.35		1-ph Jumper Problem	No
11		Cherial	Cherial town	11KV		18.35	18.50	00.15		Tree branch fell on line	No
12		Gandipally	Gandipally	11KV		17.50	18.00	00.10		Pole damage	No
13		Gandipally	Ramavaram	11KV		18:00	18:25	0:25		Line touches	No
1	RR N	Jeedimetla-I	Maheshwari	11KV	Jeedimetla	16:12	17:45	1:33	EL/OL	11kv line AB Cable failed at Sub Station	No
2		Jagathgirigutta	IDA Jagathgirigutta	11KV	Medchal	06.47	07.50	01.03	EL	11KV Brass Patti cut and Replaced at Sanjaypuri Colony	No
1		Jubilee Hills	I.O.A	11KV	X	01.50	03.00	01.10	EL,OL-Rph	Cable End Kit failed near SS	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
2	HYD N	Osm. University	Keshava Nagar	11KV	V	21:55	0:50	2:55	EL	Cable fault (2No. DTR's kept off)	Arranged B/F on 11KV Seethaphal Mandi & 11KV Mettuguda fdrs