

Day Wise Energy Consumption recorded for the month of May - 2021

Report Generation Date : 12-May-2021

DAY WISE DRAWALS											Excess	SPDCL	Net LR	Un_Restc	Diff.	Week Day	G.H. Cons.
Date	MBN	NLG	MDK	R_Tot	RR(S)	RR(N)	RR(E)	HYD	GHMC+VK B	SPDCL	Drawn	ABT Act		Cons.	in Cons.		
DAILY QUOTA	14.26	23.74	20.8	58.8	21.94	6.97	5.44	19.53	53.88	112.68							
1-May-21	17.19	16.25	18.67	52.11	9.1	10.6	6.27	24.35	50.32	102.42	-10.26	117.57	0	117.57	15.15	SATURDAY	50.31
2-May-21	17.34	17.51	18.79	53.64	9.02	10.12	6.01	25.38	50.53	104.16	-8.52	117.83	0	117.83	13.67	SUNDAY	50.53
3-May-21	17.53	18.22	18.88	54.63	8.21	11.31	6.56	26.26	52.34	106.96	-5.73	123.4	0	123.4	16.44	MONDAY	52.33
4-May-21	17.04	17.4	18.93	53.37	8.14	11.27	6.36	25.45	51.22	104.59	-8.09	117.91	0	117.91	13.32	TUESDAY	51.22
5-May-21	16.48	17.35	18.12	51.95	8.17	10.94	6.46	26.3	51.87	103.81	-8.87	116.23	0	116.23	12.42	WEDNESDAY	51.86
6-May-21	16.37	16.95	16.92	50.24	7.78	11.34	6.56	26.29	51.97	102.22	-10.46	115.68	0	115.68	13.46	THURSDAY	51.98
7-May-21	16.75	17.42	17.81	51.98	8.31	11.57	6.35	27.24	53.47	105.45	-7.23	118.14	0	118.14	12.69	FRIDAY	53.47
8-May-21	16.68	17.7	18.22	52.6	8.48	11.76	7.12	27.72	55.08	107.68	-5	119.43	0	119.43	11.75	SATURDAY	55.08
9-May-21	16.68	17.39	17.31	51.38	7.91	10.81	6.23	26.54	51.49	102.87	-9.81	116.87	0	116.87	14	SUNDAY	51.49
10-May-21	16.75	17.28	17.72	51.75	7.96	12.25	6.95	28.58	55.74	107.49	-5.19	119.41	0	119.41	11.92	MONDAY	55.74
11-May-21	15.6	16.53	17.42	49.55	7.81	12.55	7.22	29	56.58	106.13	-6.55	120.33	0	120.33	14.2	TUESDAY	56.58
Total	184.41	190	198.79	573.2	90.89	124.52	72.09	293.11	580.61	1153.78	-85.71	1302.8	0	1302.8	149.02		580.59
Average	16.76	17.27	18.07	52.1	8.26	11.32	6.55	26.65	52.78	104.89	-7.79	118.44	0	118.44	13.55		52.78
Max	17.53	18.22	18.93	573.2	9.1	12.55	7.22	29	56.58	107.68	-5	123.4	0	123.4	16.44		56.58

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		1		1		1			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	Total	606	3055	0	3	0	3	0	3	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	6	2	6	2	6	2			
2	NLG	144	988	3	3	3	3	3	3			
3	MDK	107	933									
4	SDPT				16		16		16			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	9	21	9	21	9	21	0	0	
	Grand Total	1082	6468	9	24	9	24	9	24	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 11.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Mahabubnagar	Jadcherla	33KV	Mahabubnagar	18.45	19.00	00.15	O/L	Due to Rain	Jadcherla	-
2		Mahabubnagar	Machanpally	33KV	Mahabubnagar	21.40	22.06	00.26	E/L	Due to Rain	Machanpally	-
3		Marikal	Kondapur	33KV	Narayanapet	19.20	20.30	01.10	E/L	Due to Rain	Kondapur	-
4		Marikal	Koukuntla	33KV	Narayanapet	19.35	01.45	06.10	E/L	Insulators Failed	Koukuntla	-
5		Marikal	Devarkadra	33KV	Narayanapet	19.40	01.45	06.05	E/L	Due to Rain	Devarkadra	-
6		Marikal	Koilkonda Water GRIDD	33KV	Narayanapet	19.30	20.37	01.07	E/L	Due to Rain	Koilkonda Water GRIDD	-
1	NLG	Gudapur	N.S.Batla	33KV	Nalgonda	14.50	17.50	03.00	EL	Moment Falt Tree fallen the line	N.S.Batla	-
2		Ramannapet	Chityla	33KV	Nalgonda	18.40	22.50	04.10	EL	3 Disk Failed	Chityla	-
3		Kolanpaka	Raghunadpur	33KV	Bhongiri	20.10	22.10	02.00	EL	Insuletor Failed	Raghunadpur	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 11.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Gudeballore	SATAYASAI & LIFT	11KV	Narayanpet	08.10	09.10	01.00		11KV Conductor cut at Nallagattu	-
2		DHANWADA	MANDIPALLY	11KV	Narayanpet	07.15	08.00	00.45		Insulator Failed at Mandipally AGL	-
1	NLG	Thurkapally	M.Gowram	11KV	Nalgonda	17.00	18.30	01.30	EL	Insuletoar Failed	-
2		Thurkapally	Hyblaboor	11KV	Nalgonda	17.30	18.30	01.00	EL	Jumper cut	-
3		Penpahad	Dubbathanda	11KV	Suryapet	05.30	08.40	03.10	EL	Jumper cut	-
1	SDPT	Pullur	Pullur	11KV	Siddipet	14.20	18.10	03.50		B/D Jumper cut	-
2		Raghavapur	Peddalingareddypally	11KV	Siddipet	00.00	10.55	10.55		B/D Disk Fail	-
3		Jagdevpur SS	Itikyal Feeder	11KV	Gajwel	17.20	18.40	01.20		11KV Jumper cut	
4		Pregnapur SS	Gundannapally AGL Feeder	11KV	Gajwel	14.47	18.20	03.33		Tree Branches has fallen 11KV line	
5		Thunki Kalsa SS	Thunki Kalsa AGL Feeder	11KV	Gajwel	18.05	18.45	00.40		11KV Line Snaped	
6		Gowraram SS	Pathure Feeder	11KV	Gajwel	14.50	18.15	03.25		Tree Branches has fallen 11KV line	
7		Gurrallasofa SS	Waddepally AGL Feeder LC.No.	11KV	Gajwel	15.06	17.50	02.44		11KV Jumper cut	
8		HUSNABAD	PANDILLA	11KV	Husnabad	12.00	04.48	07.12		B.D, (Tree branches fallen on line)	
9		HUSNABAD	PANDILLA	11KV	Husnabad	04.48	12.00	07.12		B.D, (Tree branches fallen on line)	
10		AKKANNAPET	PAKILNAYAK THANDA	11KV	Husnabad	09.36	01.12	06.00		B.D, (11 kv insulator Damaged)	
11		DHARMARAM	DHARAMARAM Rural	11KV	Husnabad	00.28	08.09	07.40		B.D (Line cut)	
12		DHARMARAM	Potharam(J)	11KV	Husnabad	09.36	02.52	07.40		B.D , (Insulator Failure)	
13		REGULAPALLY	CHEELAPUR	11KV	Husnabad	00.00	08.24	08.24		B.D (LINE CUT)	
14		Mustyal	Veerannapet	11KV	Husnabad	07.12	10.48	03.36		B.D, (Tree branches fallen on line)	
15		Guruvannapet	Posanpally	11KV	Husnabad	09.36	02.24	07.12		B.D, (Tree branches fallen on line)	
16		Komuravelly	Komuravelly Agl	11KV	Husnabad	07.12	07.12	00.00		B.D (Line cut)	
1	RR N	Devarayamjal	Kottapet	11KV	Medchal	14.45	15.40	00.55	BD	11KV Conductor Snapped & Replaced at VRL Company, Yamjal	-
1	RR E	Nagaram	Bandlaguda	11KV	Habsiguda	17.50	19.14	01.24		11KV Line cut at Bandlaguda Chourastha	-
1	HYD N	Green Lands	Hindu	11KV	IV	04.37	05.46	01.09		Cable End fault at Topaz building	-