

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	1	11	1	11	1	11			
7	RR(E)	168	403		14		14		14			
8	Hyd	194	1044		26		26		26			
	Total	606	3055	1	51	1	51	1	51	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849									
2	NLG	144	988		6		6		6			
3	MDK	107	933	3	7	3	7	3	7			
4	SDPT			3	6	3	6	3	6			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	6	19	6	19	6	19	0	0	
	Grand Total	1082	6468	7	70	7	70	7	70	0	0	

TSSPDCL - LMRC / Corporate office

Date: 14.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Singoor	Mission Bhageeratha	33KV	Jogipet	15:55	18:20	2:25		B/D Due to Insulator Failure	Mission Bhageeratha	No
2		R.C.Puram	JK Fenner	33KV	Patancheru	15.45	18.45	03.00		Tree branch fallen on the line	JK Fenner	No
3		Gummadidala	AFA	33KV	Patancheru	12.35	14.55	02.20		B/D Due to Jumper Cut	AFA	No
1	SDPT	Thunkibollaram	Markook	33KV	Gajwel	2:50	7:30	4:40		BD (EL Fault)	Markook	No
2		Habsipur	Pothareddypaet	33KV	Siddipet	18.15	19.10	00.55		B/D Due To Rain	Pothareddypaet	No
3		Husnabad	Dharmaram	33KV	Husnabad	16.40	17.10	00.30		BD (Jumper cut)	Dharmaram	At 17.10 hrs. Alternate supply arranged from 132KV Shangaam - 33KV Shanigaram feeder
1	RR N	132KV Medchal	Kompally	33KV	Medchal	18:47	20:34	1:47		33KV Line AB Switch Opened at Kompally Bridge	Kompally	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	NLG	Kasarabadha	Khampahad	11KV	Suryapet	3:05	6:45	3:40	EL	Conductor snapped	No
2		Keethavarigudem	Velidanda	11KV	Huzurnagar	05.20	07.00	01.40	EL	11 KV LINE SNAPPED	No
3		B.Ramaram	Saiteja Indl	11KV	Bhongiri	14.30	16.30	02.00	EL/OL	11kv Pin Insulator Failed near Maisamma Gutta	No
4		Mothkur	Mothkur Town	11KV	Bhongiri	21.15	22.25	01.10	EL/OL	11kv Insulator Failed near Rajannagudem	No
5		D.Nagaram	D.Nagaram Agl	11KV	Choutuppal	15.00	16.44	01.44	EL/OL	11kv Pole Damedged near Rachakonda	No
6		Voligonda	Mandhapuram	11KV	Choutuppal	6:30	9:41	3:11	EL/OL	11kv Disc Failed near Sai Reddy Gudem	No
1	MDK	Isnapur	Patodia	11KV	Sangareddy	17:10	18:20	1:10		11KV Conductor Snapped	No
2		Kistareddypet	Patelguda	11KV	Patancheru	17.20	19.10	01.50		Jumper Cut	No
3		Kistareddypet	Green Filed	11KV	Patancheru	18.40	20.10	01.30		11KV Jumper Cut	No
4		Kistareddypet	Industrial	11KV	Patancheru	17.20	19.40	02.20		11KV Conductor Snapped	No
5		Bollaram - I	NCL	11KV	Patancheru	15.45	19.15	03.30		Tree branch fallen on the line	No
6		Bollaram - I	Kythan	11KV	Patancheru	15.45	18.30	02.45		Tree branch fallen on the line	No
7		Bollaram - I	Soubagya	11KV	Patancheru	18:10	21:05	2:55		Tree branch fallen on the line	No
1	SDPT	JAGADEVPUR SS	AGL FEEDER	11KV	Gajwel	16:39	17:24	0:45		LT LINE CUT	No
2		THIUNKI KHALSA SS	SHAKARAM	11KV	Husnabad	02.20	08.00	05.40		11KV LINE CUT	No
3		Husnabad	Town II	11KV	Husnabad	05.45	06.45	01.00		DTR HG fuse wire problem	No
4		Husnabad	Town I	11KV	Husnabad	19.05	19.25	00.20		Control switch jumper open	No
5		Koheda	Teegalakuntapally	11KV	Husnabad	17.10	17.40	00.30		Insulator failed	No
6		Koheda	Sriramulapally	11KV	Husnabad	17:20	17:50	0:30		Line cut	No
1	RR N	Aleap	RGK	11KV	Jeedimetla	16:42	18:20	1:38	EL/OL	Endkit failed at Vishwa hight, RGK	No
2		Aleap	Pragathinagar	11KV	Jeedimetla	16.50	18.20	01.30	EL/OL	Tripped on EL/OL Indication {Due to havy Rain}	No
3		Bahadurpally	Indiramma Colony	11KV	Jeedimetla	16.15	17.20	01.05	EL/OL	Tripped on EL/OL Indication {Due to havy rain}	No
4		Jagathgirutta	IDA	11KV	Medchal	16.38	18.10	01.32		11KV Jumper cut at Devamma Basti	No
5		Subhash Nagar	Gayatri Nagar	11KV	Medchal	16.30	17.58	01.28		Tree fallen on 11KV Line at Page Collage	No
6		Bachupally	AC Tyries	11KV	Kukatpally	17.30	19.00	01.30	EL	Tree fallen the 11kv line at Mamatha Hospital	No
7		Aliabad	HBL	11KV	Medchal	05.10	08.45	03.35		Tree and Lizard fallen on 11KV Line at Sangeetha Funcation Hall	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
8		Shameerpet	Thumkunta	11KV	Medchal	06.05	09.55	03.50		11KV Cable endkit failed in SS	Backfeeding arranged from Thumkunta SS
9		Rajabollaram	Rajabollaram Thanda	11KV	Medchal	12.29	13.30	01.01		11KV Pole damaged by Lorry at Gubber Thanda	No
10		Medchal	Checkpost	11KV	Medchal	17.30	18.55	01.25		11KV Disc failed at Ravalkole Comman	No
11		Medchal	Water Grid	11KV	Medchal	17:30	19:50	2:20		11KV Disc failed at Medchal Bus Stop	No
1	RR E	Nacharam indore	Gowthami paipes	11KV	Habsiguda	16:45	17:50	1:05		11KV Disk fail at Road no 16 IDA nacharam	No
2		Strre tno 8	Laxmi nagar	11KV	Habsiguda	16.16	18.40	02.24		11kv Jumper & line cut at Madhura nagar & breaker problem	Back feeding from Doordarshan feeder
3		Strre tno 8	Greenhills	11KV	Habsiguda	16.24	18.08	01.44		Tripped on EL due to wind & rain & tree branches fallen on 11KV At Hiraiah Hospital	No
4		Uppal	RTA	11KV	Habsiguda	15.55	18.47	02.52		11KV line Snapped at Survey colony	No
5		Uppal	Bank colony	11KV	Habsiguda	16.18	17.18	01.00		DTR Brash patti cut at Sri Appt beerapagadda	No
6		Uppal	Navbharath	11KV	Habsiguda	15.57	19.50	03.53		Tree branches fallen on 11kv Amruthajan company	No
7		IDAuppal	Srikrishna	11KV	Habsiguda	16.14	21.24	05.10		Insulator fail at Airtel Opp & Jumper open	No
8		Moula ali	Gayatri Nagar	11KV	Sainikpuri	02.20	03.10	00.50		Cable failed near Moula ali Kamman Due to Gayatri Nagar laod added on Gandhi Nagar	No
9		AS Rao Nagar	BSNL	11KV	Sainikpuri	02.36	03.40	01.04		Insulator failed at Satyanad Palace near BSNL	No
10		Cherlapally-V	Ruchi Oil	11KV	Sainikpuri	02.30	04.08	01.38		Post of Insulator failed at Velocity Company and Heavy Rain fallen	No
11		AS Rao Nagar	AS Rao Nagar	11KV	Sainikpuri	05.39	07.15	01.36		Insulaotr failed at Santosh Hospital Main Road	No
12		Aushapur	NFC nagar	11KV	Keesara	14.08	15.50	01.42		Tree branches fallen on 11kvline at NFC nagar	No
13		Aushapur	Bokkenguda	11KV	Keesara	14.08	18.40	04.32		2 nos pole broken & tree branches fallen on 11kvline at Ghanapur	No
14		Aushapur	Chandupatlaguda	11KV	Keesara	14:08	19:10	5:02		2 nos pole broken & tree branches fallen on 11kvline at Maripalliguda	No
1		Chilkaiguda	New Boiguda	11KV	V	02.42	03.55	01.13	EL	No Visible Fault	Arranged B/F on 11KV C.C.Nagar fdr
2		I.D.P.L	Sakshi	11KV	VI	16:01	17:25	1:24	EL,OL-R&Bph	Big tree fallen on lines at Plot No.86	No
3		Tirumalagiri	Officers Colony	11KV	C-VI	16:05	17:06	1:01	EL,OL-Bph	No Visible Fault	No
4		R.P Nilayam	Vaishnavi Matha Temple	11KV	C-VI	16:10	17:48	1:38	EL	No Visible Fault	No
5		Gunrock	Tirumalagiri	11KV	C-VI	16:10	18:25	2:15	OL-R&Bph	No Visible Fault	No
6		Macha Bollarum	Radha Sath Sang	11KV	C-VI	16:11	20:05	3:54	Opened AR	Tree branches fallen on lines at Bollarum Y-Junction	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged	
7	HYD N	Gunrock	Medchal	11KV	C-VI	16:15	17:30	1:15	EL	No Visible Fault	No	
8		Prashasan Nagar	Journalist Colony	11KV	X	16:15	18:20	2:05	EL	No Visible Fault	No	
9		Alwal	Bhupathi Rao Nagar	11KV	C-VI	16:16	19:02	2:46	EL,OL-Bph	Tree branches fallen on lines at Anand Darshini DTR & Sai Reddy Colony	No	
10		Addagutta	Addagutta	11KV	C-VI	16:17	17:57	1:40	EL	No Visible Fault	No	
11		Lalaguda	Shanthi Nagar	11KV	V	16:20	17:45	1:25	Opened AR	No Visible Fault	No	
12		Lalaguda	Chenna Reddy	11KV	V	16:22	18:00	1:38	EL	Tree branches fallen on lines at Baptist Church	No	
13		Srinagar Colony	Kamalapuri Colony	11KV	X	16:22	17:30	1:08	EL	No Visible Fault	No	
14		Gunrock	Bowenpally	11KV	C-VI	16:25	17:50	1:25	EL	Sparking AB Switch at HMR Plaza	No	
15		Gunrock	Lal Bazar	11KV	C-VI	16:26	18:50	2:24	EL,OL	HT Jumper cut at P & T Colony	No	
16		Bhudevi Nagar	Yadamma Nagar	11KV	C-VI	16:35	17:50	1:15	EL,OL	Twisted Lines at Khanajiguda	No	
17		Tirumalagiri	Vengopal Rao Nagar	11KV	C-VI	16:40	19:15	2:35	EL,OL-R&Bph	Tree branches fallen on M.D.F American DTR	No	
18		Clock Tower	Natraj	11KV	V	22.35	01.10	02.35	EL	Cable fault at Natraj Theater	At 00:59Hrs partial fdr charged & remaining loads added on 11KV C.T.C. fdr	
1		HYD S	Petlaburz	Murali Nagar	11KV	III	01.10	02.20	01.10	OL-Rph	End Kit failed at Murali Nagar	No
2			Asmangadh	Saidabad Colony	11KV	VIII	15:50	17:05	1:15	EL	No Visible Fault	No
3			Malakpet B-Block	Akber Bagh	11KV	VIII	16:13	18:22	2:09	OL-Rph	Tree fallen on lines at Lizzad Papad & Jumper cut near SS	No
1		HYD C	Amberpet	Golnaka	11KV	II	01.22	02.25	01.03	All Indication	O/G Bph Jumper cut at SS	No
2			Zamistanpur	Jamai Osmania	11KV	II	16.10	17.15	01.05	EL	No Visible Fault	No
3			Aditya Towers	Surya Tower	11KV	VII	16.14	17.37	01.23	EL,OL	Tree branches fallen on lines at Surya Nagar	No
4	Zamistanpur		L.N Nagar	11KV	II	16:20	17:30	1:10	EL,OL-Bph	No Visible Fault	No	
5	Industrial Area		Mother Dairy	11KV	II	16.25	18.52	02.27	EL	Tree branches fallen on lines	Arranged B/F on 11KV Ram Nagar fdr	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
------	--------	-----------------------	-------------------------	-----	-------------------------	------	----	----------	---------------------	--------------------	---------------------------