

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		10		10		10			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		13		13		13			
	Total	606	3055	0	24	0	24	0	24	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	9	0	9	0	9			
2	NLG	144	988	2	16	2	16	2	16			
3	MDK	107	933	3	10	3	10	3	10			
4	SDPT			4	26	4	26	4	26			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	Total	476	3413	9	61	9	61	9	61	0	0	
	Grand Total	1082	6468	9	85	9	85	9	85	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 16.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	NLG	Wadapally	A.D.Pally	33KV	Miryalaguda	11.30	12.40	01.10	E/L	Tree falen on 33KV line		-
2		Kanagal	Pagidimarri	33KV	Nalgonda	14.05	16.02	01.57	E/L	Jumper cut		-
1	MDK	Sadasivpet	Munipally	33KV	Sangareddy	14.50	19.05	04.15		B/D due to Tree branches fallen on the line		-
2		Narayankhed	Wasar	33KV	Jogipet	13.50	17.30	03.40		B/D due to Insulator failed		-
3		Zaheerabd	Jharasangam	33KV	Zaheerabd	13.15	14.55	01.40		B/D due to Disk failed		-
1	SDPT	Habsipur	Khajipur	33KV	Siddipet	12.45	14.10	01.25		B/D Disk problem		-
2		Chandlapur	Jakkapur	33KV	Siddipet	13.10	15.20	02.10		B/D Jumper cut		-
3		Thunkibollaram	Markook	33KV	Gajwel	11.32	12.28	00.56		BD (Heavy rain)		-
4		Thukkapur	Mettu	33KV	Gajwel	12.25	13.40	01.15		BD (Tree cutting)		-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 16.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Prashanth	11KV	Jadcherla	11.23	14.50	03.27		BD due to tree follen on 11 KV line near Prashanth poultry pharm LC taken by LM Ramchandraiah for tree cutting 9963254572	-
2		Kankurthy	Lokurthy	11KV	Narayanpet	08.29	10.43	02.14		Break down due to jumper cut at Near Lokurthy vg	-
3		Kankurthy	Lokurthy	11KV	Narayanpet	11.20	13.10	01.50		Break Down due to heavy gale and wind, 11KV jumper cut at Piddampally vg	-
4		Gandeed	Salkarpet	11KV	Narayanpet	11.40	12.30	00.50		Break Dwon due to 11Kv Disc failed at Govindpally Tanda	-
5		Makthal	Chandapur	11KV	Narayanpet	05.00	07.00	02.00		Break Down due to Heavy gale and wind	-
6		Makthal	Neredgam	11KV	Narayanpet	04.00	06.10	02.10		Break Down due to Heavy gale and wind	-
7		Makthal	Khanapur	11KV	Narayanpet	04.45	07.30	02.45		Break Down due to Heavy gale and wind	-
8		Makthal	Sangambanda	11KV	Narayanpet	03.25	06.00	02.35		Break Down due to Heavy gale and wind	-
9		Thangidi	Kusumurthi	11KV	Narayanpet	11.00	13.30	02.30		Break Down due to 11Kv Insulator fail at Kusumurthi agl	-
1	NLG	Dhupahad	New Banjarahills thanda	11KV	Suryapet	11.20	12.38	01.18	E/L	Insulator flashover	-
2		D Nagaram	W.Kota	11KV	Suryapet	10.00	12.40	02.40	E/L	Disk failed	
3		Akupamula	Singaram	11KV	Huzurnagar	00.30	07.45	07.45	EL	11 KV LINE SNAPPED	
4		Ponugodu	Kothagudem	11KV	Huzurnagar	06.10	08.00	01.50	EL	11 KV LINE Tree fallen	
5		Dirsincherla	Yallapuram	11KV	Huzurnagar	04.00	07.30	03.30	EL	11 KV DISK FAILED	
6		Garidepally	Ponugodu	11KV	Huzurnagar	05.00	08.00	03.00	EL	11 KV LINE SNAPPED	
7		Gondiryala	Chimiryala	11KV	Huzurnagar	10.10	13.10	03.00	EL	Control AB open	
8		Thipparthy	Sarvaram	11KV	Nalgonda	09.30	13.10	03.40	EL	11 KV Line Jumper Cut	
9		Thipparthy	Gg Palem	11KV	Nalgonda	09.45	13.10	03.25	EL	11 KV Line Jumper Cut	
10		Thipparthy	Marrigudem	11KV	Nalgonda	09.30	13.15	03.45	EL	11 KV Line Jumper Cut	-
11		Thipparthy	Silarmiyagudem	11KV	Nalgonda	09.30	15.25	05.55	EL	Movement Failt	-
12		Pazzur	Pedda Suraram	11KV	Nalgonda	09.45	13.50	04.05	EL	11 KV Line Jumper Cut	-
13		Koppole	Koppole	11KV	Nalgonda	10.40	13.20	02.40	EL	11 KV Line Jumper Cut	-
14		Nakrekal	Policestation	11KV	Nalgonda	09.40	10.20	00.40	EL	11 KV Line Jumper Cut	-
15		Thadakamalla	Settipalem	11KV	Miryalaguda	05.30	10.30	05.00		11KV line Snapped and tree fallen on the line due to heavy gale and wind	-
16		Seethya thanda	Thopucherla	11KV	Miryalaguda	11.40	13.10	01.30		11KV Jumper cut near SS	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Sangareddy Town-I	Collector	11KV	Sangareddy	15.05	15.45	00.40		BD due to Tree branches fallen on line	-
2		Sangareddy Town-II	No-II	11KV	Sangareddy	12.04	12.43	00.39		BD due to Tree branches fallen on line	-
3		Sadasivpet Town	Nandi Kandi	11KV	Sangareddy	13.20	14.47	01.27		BD due to Conductor snapped	-
4		EPIP-II	Export	11KV	Sangareddy	17.44	19.12	01.28		BD due to Disk failed	-
5		EPIP-II	Srinivasa Costing	11KV	Sangareddy	14.35	15.33	00.58		BD due to Tree branches fallen on line	-
6		Bonthapally	Jayashanker	11KV	Patancheru	14.20	17.00	02.40		BD due to Tree branches fallen on line	-
7		Inole	Indresham	11KV	Patancheru	16.47	18.47	02.00		BD due to Tree branches fallen on line	-
8		Inole	Pedda Kanjarla	11KV	Patancheru	16.40	20.00	03.20		BD due to Tree branches fallen on line	-
9		Patancheru Town	MIA-I	11KV	Patancheru	16.15	17.40	01.25		BD due to Jumper cut	-
10		Patancheru Town	Town	11KV	Patancheru	16.20	17.25	01.05		BD due to Tree branches fallen on line	-
1	SDPT	Venkatapur	Bussapur	11KV	Sidsdipet	17.27	23.50	06.23		B/D - Stil continue Single phase given	
2		Jakkapur	Shaniga kunta	11KV	Sidsdipet	05.26	17.30	12.04		B/D for 11 Kv Jumper Cut lino. 7179	
3		Jakkapur	Gopulapur	11KV	Sidsdipet	18.04	18.50	00.46		B/d for 11 KV insulater problem lino. 7180	
4		Habsipur	Habsipur	11KV	Sidsdipet	19.55	21.28	01.33		B/D - DTR problem only single phase continue	
5		Gajwel	Mutrajpally	11KV	Gajwel	10:15	14:30	04:15		TREE BRANCH FALL OVER 11 KV	
6		Kodakandla	Kodakandla AGL	11KV	Gajwel	12.30	13.15	00.45		TREE BRANCH FALL OVER 11 KV	
7		Pamuparthi	Vasundhara Exp.	11KV	Gajwel	12.34	14.46	02.12		INSULATOR FAILED	
8		Markook	Bhavanandapur	11KV	Gajwel	07.50	08.35	00.45		EL TRIPPING	
9		Wardarajpur	Shivar Venkatapur	11KV	Gajwel	16.25	17.16	00.51		DTR EARTHING TOUCHED TO CROSS ARM	
10		Ganeshpally	Angadikistapur & Ganeshpally town	11KV	Gajwel	11.55	15.00	03.05		INSULATOR & COPPER PATTI BURNT	
11		Vantimamidi	R&R Colony	11KV	Gajwel	09.40	12.55	03.15		INSULATOR FAILED	
12		Marpadga	MarpadgaAGL-I	11KV	Gajwel	22.35	10.35	12.00		11KV LINE CUT	
13			Khammampally Agl	11KV	Gajwel	11.45	14.00	02.15		INSULATOR FAILED	
14			Sirisinagandla Agl	11KV	Gajwel	11.45	18.10	06.25		DISC FAILED	
15		Duddeda	Industrial	11KV	Gajwel	13.00	13.55	00.55		TREE BRANCH FALL OVER 11 KV	
16			Duddeda Town	11KV	Gajwel	15.12	15.32	00.20		HT / LT	
17		Govindapur	Govindapur	11KV	Gajwel	15.00	17:48	02:48		TREE BRANCH FALL OVER 11 KV	
18		Dommata	Surampally	11KV	Gajwel	13:08	15:17	01:09		JUMPER CUT	
19		Anajipur	Anajipur	11KV	Gajwel	14.24	15.52	01.28		INSULATOR FAILED	
20		Nagapuri	Shabhashgudem	11KV	Husnabad	08.40	09.40	01.00		Disk Fail	
21		Nagapuri	GandikuntA	11KV	Husnabad	14.40	16.15	01.35		Line fault	
22		Akunoor	Akunur agl	11KV	Husnabad	11.00	15.25	04.25		Line snapped	
23		Musthyal	veerannapet	11KV	Husnabad	07.25	10.50	03.25		Line snapped	
24		Gagillapur	Vallampatla	11KV	Husnabad	11.18	13.31	02.13		Fallen on the tree	
25		Guruvannapet	Guruvannapet	11KV	Husnabad	05.40	18.30	12.50		Insulator Fail	
26		Kumuravelli	Gouraipalli	11KV	Husnabad	12.20	13.20	01.00		Line fault	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	RR N	Mayurinagar	Ramnaresh nagar cable feeder	11KV	Kukatpally	17.05	18.09	01.04	EL/OL	11KV Cable failure near Cheruvu katta	-
2		Vijayanagar colony	A S Rajunagar	11KV	Kukatpally	16.55	18.30	01.35	OL	Pin insulator failure at A S Rajunagar common	-
3		Prashanth Hills	Prashanth Hills	11KV	Kukatpally	16.45	18.00	01.15	EL	Garden Lizard fallin on the AB Switch at Maduranagar common	-
4		Aliabad	HBL	11KV	Medchal	01.00	02.00	01.00	EI	Tree Fallen on 11KV Line at Sangeetha Funcation Hall	-
5		Devarayamjal	Kottapet	11KV	Medchal	05.00	07.40	02.40	EI	11KV Pole damaged and rectified at Kompally Bridge	-
6		Thumkunta	Thumkunta	11KV	Medchal	11.26	15.23	03.57	EI	Tree fallen on the 11KV Line at Excellent college	-
7		Laxmapur	IDA Laxampur	11KV	Medchal	11.25	12.55	01.30	EL/OL	Tree Fallen on 11KV Line at Durgamma Temple,MC Pally	-
8		Laxmapur	Laxmapur	11KV	Medchal	11.25	12.35	01.10	EL/OL	11KV Pin Insulator Failed at Laxmapur Cheruvu	-
9		Laxmapur	MC Pally	11KV	Medchal	11.25	13.00	01.35	OL	11KV Pin Insulator Failed at Lingapur Thanda	-
10		Gowdavelly	Basaragadi	11KV	Medchal	14.30	16.40	02.10	EL	11KV Line cut at Basaragadi Village	-
1	RR E	Narapally	Industrial	11KV	Keesara	17.12	18.18	01.06		Tree branches fallen on 11KV Line at narapally main road	-
1	HYD N	Prashanth Nagar	Andhra Jyothi	11KV	VI	16.15	17.20	01.05	EL	Jumper cut at Andhra Jyothi Press	-
2		Prashanth Nagar	Journalist Colony	11KV	X	15.58	17.06	01.08	EL,OL	No Visible Fault (Due to Rain)	-
3		Toli Chowki	Road No.86	11KV	X	16.19	17.35	01.16	EL,OL	No Visible Fault (Due to Rain)	-
4		Bora Banda	Kalyan Nagar Park	11KV	IV	16.00	18.05	02.05	EL,OL-Rph	Pin Insulator flash over at Kalyan Nagar	-
1	HYD C	Golconda	Vinobha Nagar	11KV	VII	15.58	17.15	01.17	EL	No Visible Fault (Due to Rain)	-
2		Langer House	Defence Colony	11KV	VII	16.16	17.23	01.07	EL,OL-Bph	Pin Insulator flash over at Grave Yard	-
3		Langer House	Fathe Darwaza	11KV	VII	16.27	19.20	02.53	EL,OL-R&Yph	Pin Insulator flash over at Noorani Masjid	-
4		Ibrahimbagh	New Military	11KV	VII	16.36	20.42	04.06	EL,OL	Tripping Coil fault at SS	Arranged B/F on 11KV Osman Sagar feeder
5		Golconda	Golconda OH	11KV	VII	17.10	18.40	01.30	EL,OL-Rph	Tree branches fallen on lines at Deccan Park	-
6		Golconda	Vinobha Nagar	11KV	VII	17.20	19.15	01.55	EL,OL-Rph	AB Cable fault at Mini O.U. Colony	-
7		Toli Chowki	Hakimsha	11KV	VII	17.45	18.47	01.02	EL,OL-Rph	1st Line Switch AB Cable End Kit fault at Hakimsha (1No. DTR kept off)	-
8		Aditya Towers	Delux Colony	11KV	VII	17.50	20.25	02.35	EL	AB Cable fault at Janaki Nagar Gate No.4	-
9		Industrial Area	Mother Dairy	11KV	II	19.01	20.20	01.19	EL,OL-Yph	Cable fault at Ram Nagar E-Seva (4Nos. DTRs kept off)	-