

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044		1		1		1			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>4</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	2	2	2	2	2			
2	NLG	144	988		3		3		3			
3	MDK	107	933									
4	SDPT				9		9		9			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>14</b>	<b>2</b>	<b>14</b>	<b>2</b>	<b>14</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>2</b>	<b>18</b>	<b>2</b>	<b>18</b>	<b>2</b>	<b>18</b>	<b>0</b>	<b>0</b>	

## TSSPDCL - LMRC / Corporate office

## Circle-wise 33KV Breakdowns

Date: 02.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Maddur	Kothapally	33KV	Narayanpet	16.45	18.15	01.30	E/L	Bird Fallen on the Line	Kothapally	-
2		Puttapad	Salkarpet	33KV	Narayanpet	13.10	15.45	02.35	E/L	Tree Fallen on the Line	Salkarpet	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 02.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	KOTHAPALLY	KOTHAPALLY	11KV	Narayanpet	13.55	14.10	00.15		11kv jumper cut at kommur thanda	-
2		NARAYANPET	NARAYANPET TOWN (CIVIL)	11KV	Narayanpet	15.00	15.20	00.20		Tree branch touching to 11kv line at new bus stand	-
1	NLG	Nuthankal	Yelkapally	11KV	Suryapet	05.40	08.30	02.50	E/L	Conductor snapped	-
2		Garidepally	Appanapet	11KV	Huzurnagar	00.20	08.00	07.20	EL	11 KV LINE SNAPPED	-
3		Keethavarigudem	Sarvaram	11KV	Huzurnagar	04.20	08.30	04.10	EL	11 KV LINE SNAPPED	-
1	SDP	Laxmidevipally	Ibrahimpur	11KV	Siddipet	00.00	08.30	08.30		B/D for Insulator fail	-
2		MULUGU	MULUGU HEADQUATERS	11KV	Gajwel	12.15	13.45	01.30		TREE BRANCH FELL ON 11KV LINE	-
3		DOMMATA	INDUSTRIAL	11KV	Gajwel	15.40	16.40	01.00		DTR విద్యుత్తు	-
4		RAMPUR	GROUP CONTROLL	11KV	Gajwel	18.22	19.40	01.18		కస్ట్ డౌన్	-
5		Ramachandrapur	Ramachandrapur Town	11KV	Husnabad	14.10	16.20	02.10		Jumper Cut	-
6		Mustyala	Chunchunakota	11KV	Husnabad	09.50	16.20	06.30		HT/LT Problem	-
7		Komuravelli	Inapur 24Hrs	11KV	Husnabad	08.30	13.31	05.01		Tree banch fallen on line, same rectified	-
8		Rebarthy	Ladnoor AGL	11KV	Husnabad	12.01	13.55	01.54		Tree banch fallen on line, same rectified	-
9		Bekkal	Kutigal	11KV	Husnabad	02.00	06.00	04.00		Tree banch fallen on line, same rectified	-
1	RR N	GP Pally	Neighbourhood	11KV	Medchal	05.10	08.40	03.30	EL	Breaker Mechanical Problem	-
2		Bandamadaram	Barmajiguda	11KV	Medchal	12.00	12.20	00.20	OL	Breaker Mechanical Problem(Alternate Supply Arrange from Lingapur feeder)1477.7	-
1	RR E	Keesara	Vardhana	11KV	Keesara	16.09	19.46	03.37		HT/LT line twisted at Keesara Oil Vampu T/F	-
1	HYD N	Jana Priya	Bharath Nagar	11KV	IV	09.45	11.58	02.13	Opened A.R	Cable fault at Shakthi Nagar	(Only partial fdr B/D after Sectionlizer-II)