

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		9		9		9			
7	RR(E)	168	403		17		17		17			
8	Hyd	194	1044	1	13	1	13	1	13			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>1</b>	<b>39</b>	<b>1</b>	<b>39</b>	<b>1</b>	<b>39</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	2	8	2	8	2	8			
2	NLG	144	988	4	17	4	17	4	17			
3	MDK	107	933		3		3		3			
4	SDPT			2	11	2	11	2	11			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>8</b>	<b>39</b>	<b>8</b>	<b>39</b>	<b>8</b>	<b>39</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>9</b>	<b>78</b>	<b>9</b>	<b>78</b>	<b>9</b>	<b>78</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Date: 20.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthy	Solipur-2	33KV	Wanaparthy	00.10	07.20	07.10	E/L	Cotton Stick Fallen on the Line at Duddagonda viillage	Solipur-2	AB Switch Open at Pamreddypally Petrol Pump at 7:20Hrs
2		Wanaparthy	Buddaram	33KV	Wanaparthy	00.20	09.17	08.57	E/L	Due to R Phase LA Blast	Buddaram	No
1	NLG	Mattampally	Pedaveedu	33KV	Huzurnagar	3:00	11:00	8:00	EL/OL	33 kv pin insulater failed	Pedaveedu	No
2		Mattampally	Raghunadapalem	33KV	Huzurnagar	03.00	13.30	10.30	EL/OL	CT Clamp cut	Raghunadapalem	No
3		K.M.Pally	SLBC	33KV	Devarakonda	00.08	06.20	06.12	E/L	3 Pin insulators Failure and replaced	SLBC	No
4		Madgulapally	Laxmidevigudem	33KV	Miryalaguda	04.20	06.15	01.55	E/L	Moment fault	Laxmidevigudem	No

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	MOMINAPUR	AAPPIREDDYPALLI	11KV	Narayanpet	20.00	11.00	15.00		DTR Phase to phase touched at Appireddypally(V)	No
2		KOTHAPALLY	MANNAPUR	11KV	Narayanpet	07.00	11.00	04.00		Due to Disc Failed at Mannapur(V)	No
3		DAMARGIDDA	MADDELABEEDU	11KV	Narayanpet	22.20	10.30	12.10		11KV line cut at Maddelabeedu(V)	No
4		MARIKAL	P.C.KUNTA	11KV	Narayanpet	6:00	8:30	2:30		Disc Failed, insulator Fail & phase to phase at Venkatapur(V)	No
5		MARIKAL	ELIGANDLA	11KV	Narayanpet	6:00	9:00	3:00		DTR bit cutting Near Emminonipally(V)	No
6		Ponnakal	Ponnakal Agl	11KV	Jadcherla	0:00	7:05	7:05		11KV Jumper cut Near Water Tank	No
7		Ponnakal	Rachala	11KV	Jadcherla	0:00	8:25	8:25		11KV Insulator fail Near Yarrametta(V)	No
8		Boothpur	Boothpur Rural	11KV	Jadcherla	00.00	05.35	05.35		Phase to Phase Near Narsingapur (V)	No
1	NLG	Reddygudem	Maddirala	11KV	Suryapet	6:00	9:35	3:35	E/L	Conductor snapped	No
2		Imampeta	Ramlathanda	11KV	Suryapet	09.00	11.20	02.20	E/L	Insulator flashover	No
3		Keethavarigudem	K K Thanda	11KV	Huzurnagar	03.10	07.30	04.20	EL	11 KV LINE SNAPPED	No
4		Keethavarigudem	Velidanda	11KV	Huzurnagar	06.00	08.40	02.40	EL	11 KV JUMPER CUT	No
5		Mukundapuram	Dacharam	11KV	Huzurnagar	05.35	07.35	02.00	EL	11 KV LINE SNAPPED	No
6		Thurkapally	M.Gouraram	11KV	Nalgonda	07.10	10.20	03.10	EL	11KV Jumper cut	No
7		Mushampally	Mushampally AGL	11KV	Nalgonda	10.40	14.20	03.40	EL	11KV Jumper cut	No
8		Anantharam	Hanumapur	11KV	Bhongir	23.43	08.55	09.12	EL/OL	11kv Disc Failed near Thimmapuram Village	No
9		Bollepally	Jampally	11KV	Bhongir	01.40	09.45	08.05	EL/OL	11KV Disc Failed near RN Thanda	No
10		Ch.Laxmapurm	Ch.Laxmapurm	11KV	Bhongir	13.00	15.00	02.00	EL/OL	11kv Line Snapped near Ch.Laxmapurm Village	No
11		Gurraladandi	Jampally	11KV	Bhongir	01.40	10.00	08.20	EL/OL	11kv Insulator Failed near Jampally Village	No
12		Alair	Ch.Kandukur	11KV	Bhongir	05.25	08.30	03.05	EL/OL	11kv Insulator Failed near Bapannagudem	No
13		Alair 2	Alair Town	11KV	Bhongir	03.50	04.55	01.05	EL/OL	11kv Pin Insulator Failed near Alair Municipality	No
14		Sharajipet	Tangtoor	11KV	Bhongir	01.45	07.40	05.55	EL/OL	11kv Disc Failed near Tangtoor Village	No
15		Raghunathpur	Raghunathpur Indl	11KV	Bhongir	10.15	10.50	00.35	EL/OL	11kv Line Snapped near Raghunathpur Village	No
16		Ramannapet	Janampally	11KV	Choutuppal	01.40	07.05	05.25	EL/OL	11kv Insulator Failed near Janampally Villgae	No
17		Arror	AR Pally	11KV	Choutuppal	2:00	8:15	6:15	EL/OL	11kv Line Snapped near Bodhagutta	No
1	MDK	EPIP-I	GENSINTH	11KV	Sangareddy	6:20	7:31	1:11		BD due to Disc failed	No
2		Bollaram - I	Kythan	11KV	Patancheru	00.00	13.30	13.30		BD due to Jumper cut	No
3		Gummadidala	Agrobell	11KV	Patancheru	14.05	15.55	01.50		BD due to Conductor snapped	No
1		Mittapally	Mittapally	11KV	Siddipet	14:20	16:50	2:30		B/D Jumper cut	No
2		Gajwel SS	Town 1	11KV	Gajwel	00:05	1:30	01:25		Disk failed	No
3		Jagadevapur SS	Itikyala	11KV	Gajwel	01.30	08.30	07.00		1 Ph DTR failed	No
4		Ganeshpally SS	Ganeshpally AGL	11KV	Gajwel	00.35	07.40	07.05		Tree brench fallen on the line	No
5		Ganeshpally SS	Angadikistapur AGL	11KV	Gajwel	14.15	16.30	02.15		DTR Earth Patty Disconnected	No