

Status Report on Breakdowns (Urban / Rural)**Urban**

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|----------|-------------------------|----------|-------------------------------------|----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | | | | | | | | | |
| 2 | NLG | 22 | 358 | | | | | | | | | |
| 3 | MDK | 97 | 359 | | | | | | | | | |
| 4 | SDPT | | | | | | | | | | | |
| 5 | RR(S) | 53 | 234 | | | | | | | | | |
| 6 | RR(N) | 54 | 550 | 1 | 3 | 1 | 3 | 1 | 3 | | | |
| 7 | RR(E) | 168 | 403 | | | | | | | | | |
| 8 | Hyd | 194 | 1044 | 1 | 3 | 1 | 3 | 1 | 3 | | | |
| | Total | 606 | 3055 | 2 | 6 | 2 | 6 | 2 | 6 | 0 | 0 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | | 7 | | 7 | | 7 | | | |
| 2 | NLG | 144 | 988 | 10 | 16 | 10 | 16 | 10 | 16 | | | |
| 3 | MDK | 107 | 933 | 1 | | 1 | | 1 | | | | |
| 4 | SDPT | | | | 8 | | 8 | | 8 | | | |
| 5 | RR(S) | 58 | 396 | | | | | | | | | |
| 6 | RR(N) | 38 | 114 | | | | | | | | | |
| 7 | RR(E) | 22 | 133 | | | | | | | | | |
| | Total | 476 | 3413 | 11 | 31 | 11 | 31 | 11 | 31 | 0 | 0 | |
| | Grand Total | 1082 | 6468 | 13 | 37 | 13 | 37 | 13 | 37 | 0 | 0 | |

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|--------|---------------------|----------------------|------|----------------------|---------------------|-------|----------|------------------|---|-----------------------|--|
| 1 | NLG | Madugulapally | Laxmidevigudem | 33KV | Miryalguda | 21.20 (23.05.21) | 7:50 | 9:30 | E/L | Insulator failure at Mulkapatnam | Laxmidevigudem | No |
| 2 | | Madugulapally | Seethya Thanda | 33KV | Miryalguda | 19.35 (23.05.21) | 11.40 | 16.05 | E/L | Kasaram Line touched | Seethya Thanda | No |
| 3 | | Miryalguda | Avanthipuram | 33KV | Miryalguda | 21.00 (23.05.21) | 09.30 | 12.30 | E/L | 33KV Poles Damged | Avanthipuram | Alternate supply from 220KV MLG 33KV Feeder Edulagudem at 09:30 AM |
| 4 | | Miryalguda | Huzurnagar | 33KV | Miryalguda | 21.00 (23.05.21) | 09.50 | 12.50 | E/L | Insulator failure at Near Kondrapole(v) | Huzurnagar | No |
| 5 | | Miryalguda | Matoor | 33KV | Miryalguda | 21.00 (23.05.21) | 10.15 | 13.15 | E/L | Pin Insulator Failure Top fleets | Matoor | Alternate from 132KV Wadapally 33KV A.D.Pally at 22:30 |
| 6 | | Miryalguda | Edulagudem | 33KV | Miryalguda | 21.00 (23.05.21) | 09.30 | 12.30 | E/L | Tree fallen on the line | Edulagudem | No |
| 7 | | Guntipally | Thatikolu | 33KV | Devarakonda | 22.40 (23.05.21) | 10.10 | 11.30 | E/L | Pin Insulator failed | Thatikolu | No |
| 8 | | Guntipally | Yeraram | 33KV | Devarakonda | 02.20 | 07.04 | 04.44 | E/L | Moment fault | Yeraram | No |
| 9 | | Nalgonda | Anneparthi | 33KV | Nalgonda | 09.15 | 10.00 | 00.45 | O/L | Tree fallen on the line near Annepathy village | Anneparthi | No |
| 10 | | Kanagal | Koppole | 33KV | Nalgonda | 22.20 (23.05.21) | 10:45 | 12:25 | E/L | Insulator failure at Koppole village | Koppole | No |
| 1 | MDK | Pashamailaram | EPIP | 33KV | Sangareddy | 0:38 | 2:40 | 2:02 | | Tree branches fallen on the line | EPIP | No |
| 1 | RR N | 132KV Medchal | Bandamadaram | 33KV | Medchal | 16:04 | 17:04 | 1:00 | | 33KV Cable failed near 132KV Medchal SS | Bandamadaram | Backfeeding arranged from 33KV Gowdavelly from 132KV DP Pally |
| 1 | HYD N | 132KV Erragadda | SPR Hills | 33KV | KalyanNagar | 09.15 | 09.21 | 00.06 | OL R ph | Patrolling done due to cable digging by GHMC dept at Karmikanagar one no straight through joint kit provided breakdown completed after idle feeder charged stood ok at 16:44 hrs | SPR Hills | Alternate supply arranged |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|--------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|---------------------------|
| 1 | MBNR | Bijwar | MAQDUMPUR | 11KV | Narayanpet | 12.00 | 12.30 | 00.30 | | Due to erection of poles at maqdumpur vlg | No |
| 2 | | Maganoor | WORKUR | 11KV | Narayanpet | 21.30 | 02.30 | 05.00 | | Due to poles fallen down at workur vlg | No |
| 3 | | Gudeballore | KOTHAPALLY | 11KV | Narayanpet | 23.00 | 07.30 | 08.30 | | Due to 11kv line cut near 14agl | No |
| 4 | | Thangadi | KUSMURTHY | 11KV | Narayanpet | 13:26 | 16:01 | 2:35 | | Due to insulator fail at kusumurthy vlg | No |
| 5 | | MOHAMMADABAD | ANNAREDDYPALLY | 11KV | Narayanpet | 6:18 | 7:00 | 0:42 | | Due to 11kv line cut near annareddypally vlg | No |
| 6 | | MOHAMMADABAD | V.R.PALLY | 11KV | Narayanpet | 11:50 | 12:20 | 0:30 | | Due to tree branch fallen on 11kv line | No |
| 7 | | KANUKURTHY | LOKURTHY | 11KV | Narayanpet | 13.48 | 16.00 | 02.12 | | Due to 11kv jumper cut at kanukurthy vlg | No |
| 1 | NLG | Jalalpuram | Velishala | 11KV | Suryapet | 9:00 | 10:05 | 1:05 | E/L | Jumper cut and insulator failed | No |
| 2 | | Annaram | Annaram | 11KV | Suryapet | 11.00 | 12.30 | 01.30 | E/L | Conductor snapped | No |
| 3 | | Kalmalcheruvu | Ganganagar | 11KV | Huzurnagar | 03.00 | 07.30 | 04.30 | EL | 11 KV LINE SNAPPED | No |
| 4 | | Mukundapuram | Dacharam | 11KV | Huzurnagar | 05.20 | 08.00 | 02.40 | EL | 11 KV JUMPER CUT | No |
| 5 | | Gondiryala | Chimiryala | 11KV | Huzurnagar | 05.00 | 08.30 | 03.30 | EL | 11 KV LINE SNAPPED | No |
| 6 | | Bairavunibanda | N.G.Kothapally | 11KV | Nalgonda | 02.30 | 06.30 | 04.00 | EL | 11 KV JUMPER CUT | No |
| 7 | | Nidmanoor | Shakapuram | 11KV | Miryalaguda | 00.00 | 12.30 | 12.30 | EL | Disk Failed | No |
| 8 | | Thmmapuram | Kallepally | 11KV | Miryalaguda | 14.10 | 14.35 | 00.25 | EL | Tree Falen | No |
| 9 | | Kamareddygudem | Pusalapahad | 11KV | Miryalaguda | 06.50 | 09.30 | 02.40 | EL | Insulator Failed | No |
| 10 | | Kamareddygudem | Kamareddygudem | 11KV | Miryalaguda | 00.00 | 08.40 | 08.40 | EL | Disk and Tree Falen | No |
| 11 | | Mupparam | Mupparam | 11KV | Miryalaguda | 07.15 | 10.10 | 02.55 | EL | Jumper Replaced | No |
| 12 | | Mupparam | Guntakagudem | 11KV | Miryalaguda | 00.00 | 07.30 | 07.30 | EL | Conductor snaped and Replaced | No |
| 13 | | Thadakamalla | Settipalem | 11KV | Miryalaguda | 08.12 | 14.36 | 06.24 | EL | Insulator Failed | No |
| 14 | | AD Pally | Ulsaipalem | 11KV | Miryalaguda | 06.00 | 09.23 | 03.23 | EL | Insulator Failed | No |
| 15 | | Chada | Chada | 11KV | Bhongir | 04.00 | 08.30 | 04.30 | EL/OL | 11kv line snapped near Chada Village | No |
| 16 | | Voligonda | Nagaram | 11KV | Choutuppal | 9:50 | 14:15 | 4:25 | EL/OL | 11kv Line Snapped near Musi River Voligonda | No |
| 1 | SDPT | Dommata SS | Dommata | 11KV | Gajwel | 8:25 | 8:40 | 0:15 | | 11 KV jumper Cut | No |
| 2 | | MD shapur SS | Lingaipally thanda | 11KV | Gajwel | 07.20 | 09.30 | 02.10 | | 11 KV disk Fail | No |
| 3 | | Kammarlapally | Kammarlapally | 11KV | Siddipet | 13.06 | 17.07 | 04.01 | | B/D 11 Kv wire cut | No |
| 4 | | Ragothampally | Akaram | 11KV | Siddipet | 06.25 | 08.28 | 02.03 | | B/D for Tree branches fallen on the line | No |
| 5 | | Rebarthy | Rebarthy | 11KV | Husnabad | 13.46 | 14.42 | 00.56 | | line fallen on the tree | No |
| 6 | | Arjunpatla | Kamlaipalli | 11KV | Husnabad | 11.45 | 13.32 | 01.47 | | Line snapped | No |
| 7 | | HUSNABAD | MALAPALLY | 11KV | Husnabad | 09.50 | 17.00 | 07.10 | | Fallen on the line AB SWITCH PIPE | No |
| 8 | | Koheda | Kurella | 11KV | Husnabad | 8:10 | 9:10 | 1:00 | | Jumper fault | No |
| 1 | RR N | Jeedimetla-I | H M T | 11KV | Jeedimetla | 14:04 | 17:42 | 3:38 | | Crow fallen on the 11kv Line & 11kv Pin insulator failure at Tirumala Bakery | No |
| 2 | | ICICI | Bharath Biotech | 11KV | Medchal | 02.40 | 06.00 | 03.20 | | No visible fault | No |
| 3 | | Nuthankal | Bharathi | 11KV | Medchal | 08.40 | 09.30 | 00.50 | | Tree Branch fallen on the 11KV line at Bharathi | No |
| 1 | HYD N | I.I.C.T | Solex | 11KV | V | 01.26 | 03.18 | 01.52 | EL | AB Cable fault at Lalitha Residency (1No. DTR kept off) | No |
| 2 | | Osm. University | RTC Hosptial | 11KV | V | 1:30 | 2:55 | 1:25 | EL | Pin Insulator flash over at RTC Hospital | No |
| 3 | | Tirumalagiri | Srinagar Colony | 11KV | C-VI | 12:30 | 13:40 | 1:10 | EL | Jumper & Brass Patti burntout at Mahalaxmi DTR | No |