

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550		2		2		2			
7	RR(E)	168	403		1		1		1			
8	Hyd	194	1044									
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		1		1		1			
2	NLG	144	988		5		5		5			
3	MDK	107	933		2		2		2			
4	SDPT			1	14	1	14	1	14			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>22</b>	<b>1</b>	<b>22</b>	<b>1</b>	<b>22</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>25</b>	<b>1</b>	<b>25</b>	<b>1</b>	<b>25</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 25.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	SDP	Duddeda	Bandaram	33KV	Gajwel	14.45	15.05	00.20		BD ( Tree branch fallen on the line)	Bandaram	-

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 25.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Nancharla	Nancharla	11KV	Narayanpet	15.36	19.01	03.25		11kv jumper cut, supply restored	-
1	NLG	Narkatpally	M.Yedavelly	11KV	Nalgonda	10.55	12.10	01.15	E/L	Insulator Failed	-
2		Nagaram	Narsimhulagudem	11KV	Suryapet	07.45	09.45	02.00	E/L	Insulator failed	-
3		Disincherla	Yallapuram	11KV	Huzurnagar	04.10	07.30	03.20	EL	11 KV Line snapped	-
4		Chada	Chada	11KV	Bhongiri	13.45	16.50	03.05	EL/OL	11kv Line Snapped Near Chada Village	-
5		Choutuppal IPDS	Damera Agl	11KV	Choutuppal	14.22	16.34	02.12	EL/OL	11kv Line Snapped Near Damera Village	-
1	MDK	Pati	Shalimar	11KV	Patancheru	15.50	16.40	00.50		B/D Due to tree branch fallen on the line	-
2		Gundla Machnoor	Industrial	11KV	Jogipet	17.05	18.50	01.45		B/D Due to Conductor Snapped	-
1	SDP	Pregnapur	Akkaram Feeder LC.No.12529	11KV	Gajwel	12.58	17.30	04.32		11KV line fallen	-
2		Damarkunta SS	Damarakunta feeder LC.No.837	11KV	Gajwel	14.00	21.14	07.14		11 KV Line Cutting Wire	-
3		Mulugu SS	Mulugu Town Feeder LC.No.12040	11KV	Gajwel	11.50	16.02	04.12		11KV insulator fail	-
4		Mulugu SS	Nagireddy pally FeederLC.No12041	11KV	Gajwel	14.25	17.42	03.17		11KV insulator fail	-
5		Thunki Bollaram SS	Narsapur Feeder LC.No.12388	11KV	Gajwel	06.30	09.30	03.00		11KV insulator fail	-
6		Govindapur SS	Govindapur Feeder LC.No.13567	11KV	Gajwel	13.15	15.15	02.00		11KV insulator fail	-
7		Thornal	Thornal	11KV	Siddipet	10.33	11.38	01.05		B/D for Insulator fail	-
8		Nancharpally	Nancharpally	11KV	Siddipet	13.26	15.30	02.04		B/D Tree branches fallen on 11KV Line	-
9		Mittapally	Yellupally	11KV	Siddipet	14.35	15.25	00.50		B/D Tree branches fallen on 11KV Line	-
10		Narayanraopet	Beerappagudi	11KV	Siddipet	10.20	16.00	05.40		B/D for Due to bird at 11KV Line	-
11		Dubbak	Lachapet	11KV	Siddipet	14.00	15.12	01.12		B/D for 11KV Line cut LC Mo.15671	-
12		Pedda Cheekode	Pedda Cheekode	11KV	Siddipet	09.30	10.30	01.00		B/D for 11KV Line cut LC Mo.2841	-
13		Pedda Cheekode	Areppally	11KV	Siddipet	15.30	16.00	00.30		B/D for Insulator fail LC No.2842	-
14		Komaticheruvu	Kushal Nagar	11KV	Siddipet	13.50	15.30	01.40		B/D for Flexi fall on 11 KV Line	-
1	RR N	ICICI	Bharath Biotech	11KV	Medchal	14.34	15.34	01.00	BD	11KV Conductor Snapped at Bharath Petrol Bunk,Thurkapally	-
2		Aliabad	Majeedpur	11KV	Medchal	15.40	16.10	00.30	BD	11KV Line AB Switch Opened at Aliabad X Road(11KV Line touched with LT Line and rectified)	-
1	RR E	Cherlapally-III	IOC	11KV	Sainikpuri	14.15	15.25	01.10		11KV line cut at Barath Gas Company Opposite (AE/OP) due to AB Switch Open	-