

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107									
2	NLG	22	358									
3	MDK	97	359									
4	SDPT											
5	RR(S)	53	234									
6	RR(N)	54	550	4	1	4	1	4	1			
7	RR(E)	168	403		6		6		6			
8	Hyd	194	1044		8		8		8			
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>4</b>	<b>15</b>	<b>4</b>	<b>15</b>	<b>4</b>	<b>15</b>	<b>0</b>	<b>0</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849		15		15		15			
2	NLG	144	988		12		12		12			
3	MDK	107	933	1	1	1	1	1	1			
4	SDPT			1	15	1	15	1	15			
5	RR(S)	58	396									
6	RR(N)	38	114									
7	RR(E)	22	133									
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>2</b>	<b>43</b>	<b>2</b>	<b>43</b>	<b>2</b>	<b>43</b>	<b>0</b>	<b>0</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>6</b>	<b>58</b>	<b>6</b>	<b>58</b>	<b>6</b>	<b>58</b>	<b>0</b>	<b>0</b>	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 27.05.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MDK	Jogipet	Laxmi sagar	33KV	Jogipet	14.30	17.10	02.40		B/D Due to Insulator Failure	Laxmi sagar	-
1	SDPT	Shanigaram	Shanigaram	33KV	Husnabad	03.36	13.12	09.36		B.D, Due to line idle charge at Thotapally	Shanigaram	-
1	RR N	132KV Chintal	33KV Chintal	33KV	Medchal	02.52	03.25	00.33		33KV UG Cable failed at near SS Charged ok 18:45	33KV Chintal	Backfeeding arranged from 33KV Jagathgirigutta(132KV Shapur Nagar)
2		132KV LGM Pet	33KV BE Pharma	33KV	Medchal	12.24	14.08	01.44		No Fault	33KV BE Pharma	-
3		132KV Medchal	33KV Medchal-I	33KV	Medchal	12.18	14.02	01.44		Jumper Cut & Replaced at Check Post	33KV Medchal-I	-
4		132KV Medchal	33KV GP Pally-II	33KV	Medchal	03.05	05.25	02.20		33KV Cable endkit Failed	33KV GP Pally-II	(Backfeeding arranged from 33KV Maisammaguda Feeder(132KV DP Pally SS)-

## TSSPDCL - LMRC / Corporate office

## Circle-wise 11KV Breakdowns

Date: 27.05.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Manthangoud	KATROPALLY	11KV	Narayanpet	09.00	10.00	01.00		11kv insulator fail at katropally vlg	-
2		Maganoor	ADIVISATYARAM	11KV	Narayanpet	01.30	06.30	05.00		Due to removal pin binding and 11kv disc fail at achampet vlg	-
3		GUNDUMAL	AMILIKUNTA	11KV	Narayanpet	09.30	12.35	03.05		Due to 11kv insulator fail at amilikunta vlg	
4		MADDUR	DOREPALLY	11KV	Narayanpet	09.55	10.18	00.23		Due to DTR repair at dorepally vlg	
5		MADDUR	PEDIRIPAD	11KV	Narayanpet	15.10	19.43	04.33		Due to Heavy Wind & Rain	
6		KOTHAPALLY	LINGALCHEDU	11KV	Narayanpet	04.30	06.50	02.20		Tree branch fallen on 11kv line at lingalchedu vlg	
7		KOTHAPALLY	LINGALCHEDU	11KV	Narayanpet	12.35	14.45	02.10		Due to tree branch fallen on 11kv line at lingalchedu vlg	
8		NANCHERLA	NANCHARLA	11KV	Narayanpet	10.56	14.56	04.00		Due to 11kv line cut near nancherla vlg	
9		VENNACHEDU	LINGAIPALLY	11KV	Narayanpet	16.30	17.10	00.40		Due to heavy gale and wind	
10		MOHAMMADABAD	ANNAREDDYPALLY	11KV	Narayanpet	16.30	17.30	01.00		Due to heavy gale and wind	
11		CHINNAJATRAM	ANTHWAR	11KV	Narayanpet	06.15	09.15	03.00		Due to DTR fail at anthwar gate	
12		KANUKURTHY	DAMARGIDDA	11KV	Narayanpet	12.15	14.15	02.00		Due to 11KV line cut near kanukurthy vlg	
13		EKLASPUR	CHITTANUR	11KV	Narayanpet	09.30	11.50	02.20		Due to DTR fail near chittanur vlg	
14		Balanagar	Nerellapally	11KV	Jadcherla	10.50	12.00	01.10		HT/LT Near Nerellapally (Vi)	
15		Badepally	Burgupally	11KV	Jadcherla	06.35	09.30	02.55		11KV Jumper Cut Near Burgupally Thanda	
1	NLG	Nuthankal	Yerrapahad	11KV	Suryapet	06.30	08.30	02.00	E/L	11Kv Insulator failed	-
2		Dirsincherla	Chellepally	11KV	Huzurnagar	02.00	07.45	05.45	E/L	11Kv Line Snapped	-
3		Kalmalcheruvu	Ganganagar	11KV	Huzurnagar	07.00	08.50	01.50	E/L	11Kv Jumper Cut	-
4		Munagala	Barakathgudem	11KV	Huzurnagar	06.25	08.00	01.35	E/L	11Kv Disk Filed	-
5		Mukundapuram	Somaram	11KV	Huzurnagar	10.15	11.20	01.05	E/L	11Kv Line Snapped	
6		Golankonda	Vanchyagudem	11KV	Bhongir	04.00	08.50	04.50	E/L	11kv Line snapped near Jedikal (V)	
7		Sharajipet	Tangutoor	11KV	Bhongir	07.10	08.40	01.30	E/L	11kv Insulator failed bypass road	
8		Puligilla	Puligilla	11KV	Choutuppal	00.10	06.50	06.40	E/L	11kv Line snapped at SS- 12 near Puligilla (V)	
9		Eduloor	G.B.Gudem	11KV	Nalgonda	03.50	10.10	06.20	E/L	11Kv Line Jumper Cut	-
10		Nampally	Peddapuram	11KV	Devarakonda	04.00	08.00	04.00	E/L	Tree Flowen the 11Kv Line	-
11		Marriguda	Marriguda Town	11KV	Devarakonda	05.00	09.00	04.00	E/L	HT/HT	-
12		Shivannagudem	Ram reddy pally	11KV	Devarakonda	04.00	08.50	04.50	E/L	11Kv Disc Failed	-

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MDK	Kistareddypet	Beeramguda	11KV	Patancheru	16.06	16.43	00.37		B/D Due to Insulator Failure	-
1		Potharam	Nagaram	11KV	Husnabad	03.36	01.12	12.00		B.D Due to tree fallen on line	-
2		Guruvannapet	Tapaspally	11KV	Husnabad	01.12	07.12	06.00		B.D Due to tree fallen on line	-
3		Bekkal	Thornala	11KV	Husnabad	03.36	04.48	01.12		B.D Due to Heavy wind tree fallen on line	-
4		MULUGU SS	NARSAMPALLY AGL	11KV	Gajwel	09.30	10.50	01.20		HT/HT PHASE TO PHASE	
5		MULUGU SS	NARSAMPALLY AGL	11KV	Gajwel	11.20	11.55	00.35		HT/HT PHASE TO PHASE	
6		VANTIMAMIDI SS	INDUSTARIAL	11KV	Gajwel	07.25	08.50	01.15		HT/HT PHASE TO PHASE	
7	SDPT	VANTIMAMIDI SS	CHINNATHIMMAPUR	11KV	Gajwel	07.25	08.50	01.15		HT/HT PHASE TO PHASE	
8		MUBARASPUR SS	MUBARASPUR	11KV	Gajwel	11.17	12.38	01.21		11KV LINE PHASE TO PHASE	
9		GOVINDAPUR SS	GOVINDAPUR	11KV	Gajwel	07.38	09.06	01.28		HT/LT	
10		Thimmapur	Thimmapur	11KV	Siddipet	17.05	17.43	00.38		B/D Cable Bust	
11		Thimmapur	Thimmapur	11KV	Siddipet	17.52	18.15	00.23		B/D Tree Fall Down	
12		Mirdoddy	Mirdoddy	11KV	Siddipet	19.00	20.00	01.00		B/D - HT/LT Line Touch,	
13		Rudraram	Rudraram	11KV	Siddipet	09.30	17.45	08.15		B/D Tree Fall Down	
14		Narsapur	Karimnagar Indl	11KV	Siddipet	17.28	19.20	01.52		B/D Tree Fall Down	
15		Indoor	Old Bus Stand	11KV	Siddipet	17.40	19.08	01.28		B/D Tree Fall Down	
1	RR N	Town Medchal	Jyothi Nagar	11KV	Medchal	09.40	11.30	01.50		Tree Branch fallen on the 11KV Line at Jyothi Nagar	-
1		Nacharam	Durga Nagar	11KV	Habsiguda	04.24	05.19	00.55		11KV Line cut at Road No.01 IDA Nacharam	-
2		IDA Uppal	Metro	11KV	Habsiguda	18.12	19.04	00.52		11KV Brass patti cut at Dolphin Graphics Company	-
3		Nacharam Indore	Ram Reddy Nagar	11KV	Habsiguda	15.57	16.42	00.45		Tree branches fallen on 11KV line at Durga Nagar Railway Gate	-
4	RR E	Kushaiguda	Rukminipuri	11KV	Sainikpuri	06.00	08.10	02.10		Ground petrolling done but no visible fault found (AE/OP) due to AB Switch Open at Brundhavan Colony	-
5		Moula ali	Spectra	11KV	Sainikpuri	15.55	17.02	01.07		Tree branches fallen on 11Kv line at Post Office IDA Moula-Ali (Artisan Janaiah)	-
6		Cherlapally-II	Phase-IV	11KV	Sainikpuri	08.45	10.45	02.00		11Kv Pin Insulator failed at BN Reddy Nagar & Tree branches cutting (AE/OP)	-
1		Maitrivanam	Anand Bagh	11KV	IV	09.02	10.15	01.13	EL,OL	Cable fault	Arranged B/F on 11KV D.K.Road fdr
2		Alwal	Chandrapuram	11KV	C-VI	15.27	16.45	01.18	EL	Tree branches fallen on lines at Chandrapuram	----
3		Bhudevi Nagar	Yadamma Nagar	11KV	C-VI	15.48	16.55	01.07	EL	Tree branches fallen on lines at Telecom Colony & Radha Swamy Temple	----
4	HYD N	R.P Nilayam	Naga Devatha Temple	11KV	C-VI	15.48	17.55	02.07	EL	HT Jumper cut Railway Track Bridge	(Partial fdr charged at 17:10 Hrs)
5		R.P Nilayam	Vaisnavi Matha Temple	11KV	C-VI	15.55	17.18	01.23	EL,OL-Rph	Tree branches fallen on lines near Kadia Bakery	----
6		Addagutta	Shanthi Nikethan	11KV	C-VI	15.55	18.20	02.25	EL,OL-Rph	----	Arranged B/F on 11KV Ravi Colony fdr
1	HYD C	Vittalwadi	Basanth Colony	11KV	II	08.40	09.55	01.15	EL	Tree branches fallen on lines at Metro Station	----
2	HYD S	Miralam	Ansari Road	11KV	III	12.12	13.19	01.07	EL,OL	Conductor snapped at Idli Hotel	----