

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No. of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	2	0	2	0	2	0	2	
6	RR(N)	54	550	0	9	0	9	0	9	0	9	
7	RR(E)	168	403	0	3	0	3	0	3	0	3	
8	Hyd	194	1044	0	2	0	2	0	2	0	2	
	Total	606	3055	0	16	0	16	0	16	0	16	

Rural

S.No	Circle	No. of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	1	1	1	1	1	1	1	1	
2	NLG	144	988	1	6	1	6	1	6	1	6	
3	MDK	107	933	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	0	0	0	0	0	0	0	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	Total	476	3413	2	7	2	7	2	7	2	7	
	Grand Total	1082	6468	2	23	2	23	2	23	2	23	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 1.09.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	MBNR	Wanaparthi	Solipur-2	33KV	Wanaparthi	12.00	14.27	02.27		Due to Line Fault		Alternate Supply Arranged From 132KV SS Ghanapur at 14:27Hrs.
2	Yadadri	Bibinagar	Venkireyala	33KV	Bhongir	14.15	16.00	01.45		33KV Disc Failed near Palley Gudem		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 1.09.2021

S. No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Balanagar	Gouthapur	11KV	Jadcherla	14.06	16.20	02.14		11KV Wire Cut Near Chintha Gudem (V)	
2	Medchal	Jeedimetla-IV	Axies	11KV	Jeedimetla	02.50	03.55	01.05	EL/OL	11kv Pin Insultor Failure At axes Company	
3		Jeedimetla-SS-II	N R S A	11KV	Jeedimetla	01.55	03.20	01.25	EL	11kv Pin Insultor Failure At jenna Steel	
4		Devarayamjal	Kottapet	11KV	Medchal.	14.25	15.10	00.45		Tree Branch fallen on the 11KV Line at VRL Godam Backside	
5	Nalgonda	Kethepally	Dugunevelly	11KV	Nalgonda	06.00	08.15	02.15	E/L	11KV Line Jumper Cut	
6		Kethepally	Kalimera	11KV	Nalgonda	06.00	08.00	02.00	E/L	Insulator Failure	
7		Pamanagundal	Ismailpally	11KV	Nalgonda	09.30	11.15	01.45	E/L	1 NO Disk failed	
8		Pamanagundal	Pittampally	11KV	Nalgonda	09.09	11.10	02.01	E/L	11KV Line Snapped	
9	SURYAPET	Mkundapuram	Kalluru	11KV	HUZURNAGAR	05.30	07.45	02.15		11 KV LINE SNAPPED	
10		Repala	Singaram	11KV	HUZURNAGAR	06.00	07.30	01.30		11 KV JUMPER CUT	
11	RR North	Chilalguda	Dandu Pentaiah	11KV	Paradise	01.15	03.05	01.50	EL,OL-Yph	No Visible Fault	Arranged B/F on 11KV MCH Park fdr
12		Chilalguda	Rajya Laxmi Housing Corporation	11KV	Paradise	22.35	23.47	01.12	EL,OL-Rph	HG fuse fault at Rajya Laxmi Housing Corporation	
13		Alwal	HMT Officers Colony	11KV	Bowenpally	02.10	03.25	01.15	EL	Disc Insulator flash over at R.K.Homes Apartment	
14	HYD-Central	Lakeview	Katriya Hotel	11KV	Saifabad	01.58	04.00	02.02	EL,OL	Post type Insulator flash over at Vittal Rao Jewellers	
15		Z.P.Office	Banjara Avenue	11KV	Saifabad	02.32	07.07	04.35	EL,OL		
16	HYD South	Malakpet	Dabeerpura	11KV	Asmangadh	08.40	10.35	01.55	All Indication	Cable fault	Arranged partial loads B/F on 11KV Chanchalguda fdr & remaining loads on 11KV Judges Colony fdr

S. No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
17	RAJENDRA NAGAR	ICAR	Green walk	11KV	RAJENDRA NAGAR	00.40	02.01	01.21	ELOL	11kv Disk Failed & Replaced at Patti kunta, Due to rain	
18	CYBER CITY	Puppalaguda	Lancohills	11KV	IBRAHIMBAGH	00.40	02.11	01.31	EL	11KV Lanco Hills Breaker problem	33/11KV Puppalaguda & 11kv Secretariat colony
19	MEDCHAL	Jeedimetla 2	NRSA	11KV	JEEDIMETLA	01.55	03.20	01.25	EL	11kv Pin Insulator Failed & Replaced at Ginni Steel	
20	MEDCHAL	Jeedimetla 4	Axies	11KV	JEEDIMETLA	02.50	03.55	01.05	ELOL	Pin Insulator Failed & Replaced at Axies	
21	MEDCHAL	Jeedimetla 1	HMT Society	11KV	JEEDIMETLA	03.35	05.05	01.30	ELOL	Brass Pattie Cut & Replaced at Sagar Hotel, 5 No Jumper Cut & Rebinded at Rajeevi Gandhi Park, Shapur bus stop	
22	RAJENDRA NAGAR	NPA	Sastripuram	11KV	RAJENDRA NAGAR	03.58	05.22	01.24	EL	11kv Line Cut at SLI School	33kv NPA / 11kv Kings colony
23	HABSIGUDA	IDA Uppal	Ferrocast	11KV	HABSIGUDA	09.08	10.37	01.29	EL/OL	Breaker Tripping Coil Burnt in SS Yard	11KV Egg Wood From 33KV Street No-8