

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	5	0	5	0	5	0	0	
6	RR(N)	54	550	0	4	0	4	0	4	0	0	
7	RR(E)	168	403	0	15	0	14	0	14	0	0	
8	Hyd	194	1044	0	6	0	6	0	6	0	0	
	Total	606	3055	0	30	0	29	0	29	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	12	0	12	0	12	0	0	
2	NLG	144	988	0	3	0	3	0	3	0	0	
3	MDK	107	933	1	7	1	7	1	7	0	0	
4	SDPT			0	3	0	0	0	0	0	0	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	0	0	0	0	0	0	0	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	Total	476	3413	1	25	1	22	1	22	0	0	
	Grand Total	1082	6468	1	55	1	51	1	51	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 04.09.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	Sangareddy	Borapatla	Chandapur	33KV	Jogipet	18.08	20.50	02.42		B/D Due to Jumper Cut		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 04.09.2021

S. No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Cybercity	Azianagar	Srinidhi	11KV	Ibrahimbagh	14.21	14.40	00.19		EL	
2	Cybercity	Moinabad	SPS	11KV	Ibrahimbagh	13.55	14.30	00.35		EL	
3	Cybercity	Azianagar	Srinidhi	11KV	Ibrahimbagh	15.41	15.46	00.05		EL	
4	Cybercity	Azianagar	Srinidhi	11KV	Ibrahimbagh	15.41	17.28	01.47		(LC)Tree branchaces follan Line at Nagireddy guda (V)	
5	Cybercity	Moinabad	Vijaynavya	11KV	Ibrahimbagh	19.01	19.08	00.07		LC Jumper cut	
6	Habsiguda	Mallapur	Joffula	11KV	Habsiguda	03.38	03.44	00.06		Tripped on EL	
7	Habsiguda	Mallapur	JOFLO	11KV	Habsiguda	14.01	14.24	00.23		Tripped on EL Due to Heavy Rain	
8	Habsiguda	Mallapur	JOFLO	11KV	Habsiguda	17.30	17.35	00.05		Tripped on EL	
9	Habsiguda	Cherlapally-III	IOC	11KV	Sainikpuri	03.15	03.20	00.05		Tripped on EL/OL	
10	Habsiguda	Cherlapally-III	Danmed	11KV	Sainikpuri	16.05	16.10	00.05		Tripped on EL	
11	Habsiguda	Cherlapally-II	Phase-IV	11KV	Sainikpuri	04.08	04.13	00.05		Tripped on EL	
12	Habsiguda	Cherlapally-V	Pedda Cherlapally	11KV	Sainikpuri	05.05	05.10	00.05		Tripped on EL	
13	Habsiguda	Cherlapally-V	Ruchi Oil	11KV	Sainikpuri	16.24	17.04	00.40		Tripped on EL/OL (due to 11Kv line Pin Insulator failed & replacement at near Wayla City Company)	
14	Habsiguda	Uppal	Nava Bharath	11KV	Habsiguda	15.46	16.40	00.54		11KV Pin Insulater failed at Amruthanjan Company	
15	Habsiguda	Cherlapally-II	Phase-IV	11KV	Habsiguda	13.43	13.48	00.05		11Kv Brass Patti cut at near Halpa Hotel (AE/OP)	
16	Medchal	Nuthankal	Oyster	11KV	Medchal	07.25	09.35	02.10		11KV Pin Insulator failed at Lingapur Road	
17	Mahabubnagar	Serivenkatapur	Serivenkatapur	11KV	Mahabubnagar	12.50	13.43	00.53		11KV Tree fallen on conductor Near Serivenkatapur	
18	Mahabubnagar	Gundyala	Kistampally	11KV	Mahabubnagar	07.30	10.47	03.17		11KV Tree fallen on conductor at Kistampally thanda	
19	Mahabubnagar	Peddarevelly	Chinna revelly	11KV	Jadcherla	10.53	12.17	01.24		BD due to bird follen on line near chinnarevelly (v)	
20	Mahabubnagar	Boothpur	Town	11KV	Jadcherla	04.50	06.20	01.30		BD due to tree follen on 11 kv line near Boothpur town	

S. No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
21	Mahabubnagar	Krishna	KRISHNA	11KV	NARAYANPET	01.10	09.30	08.20		Breakdown due to heavy rain & wind and insulator fail at LV breaker at sub station	
22	Mahabubnagar	Krishna	THANGADI	11KV	NARAYANPET	01.10	09.30	08.20		Breakdown due to heavy rain & wind and insulator fail at LV breaker at sub station	
23	Mahabubnagar	Krishna	RAILWAY	11KV	NARAYANPET	01.10	09.30	08.20		Breakdown due to heavy rain & wind and insulator fail at LV breaker at sub station	
24	Mahabubnagar	GUNDUMAL	GUNDMAL AGL	11KV	NARAYANPET	09.45	11.00	01.15		Breakdown due to 11kv line phase to phase near peerla gutta	
25	Mahabubnagar	MADDUR	CHINTALDINNE	11KV	NARAYANPET	02.00	07.30	05.30		Breakdown due to heavy rain & wind	
26	Mahabubnagar	MADDUR	RERNIVETLA (PADRIPAD)	11KV	NARAYANPET	02.20	06.00	03.40		Breakdown due to heavy rain & wind	
27	Mahabubnagar	MADDUR	KHAJIPUR	11KV	NARAYANPET	03.30	06.00	02.30		Breakdown due to heavy rain & wind	
28	Mahabubnagar	SALKARPET	JANGAREDDYPALLY	11KV	NARAYANPET	10.00	11.30	01.30		Breakdown due to heavy rain & wind and insulator fail at gandede agl	
29	Nalgonda	Ghanpur	Polkampally	11KV	DEVARAKONDA	10.30	11.45	01.15	EL	Conductor Snapped	
30	Nalgonda	Gurrampode	Pittalagudam Feeder	11KV	DEVARAKONDA	06.22	08.30	02.08	EL	Pin insulator failed	
31	Nalgonda	Chandampeta	Dindi Rural	11KV	DEVARAKONDA	07.15	08.30	01.15	EL	Pin insulator failed	
32	Sangareddy	Sangareddy Town-I	Tallapally	11KV	Sangareddy	14.45	15.30	00.45		B/D Due to Insulator Failure	
33	Sangareddy	Sadasivpet	TSM	11KV	Sangareddy	14.17	15.25	01.08		B/D Due to Jumper Cut	
34	Sangareddy	EPIP-I	Chaitanya	11KV	Sangareddy	08.52	11.50	02.58		B/D Due to Jumper Cut	
35	Sangareddy	Anrich Bollaram	Town-II	11KV	Patancheru	19.30	20.30	01.00		B/D Due to Conductor Snapped	
36	Sangareddy	Gummadidala	Gummadidala	11KV	Patancheru	09.20	11.25	02.05		B/D Due to Conductor Snapped	
37	Sangareddy	Gummadidala	Mambapur	11KV	Patancheru	06.30	11.00	04.30		B/D Due to Insulator Failure	
38	Sangareddy	Patancheru Town	MIA-II	11KV	Patancheru	14.55	15.35	00.40		B/D Due to Jumper Cut	
39	Siddipet	DUDEEDA	IND(LC.NO:9565)	11KV	Gajwel	19.20	21.15	01.55		DISC FAILED	
40	Siddipet	Dharmaram	Nandaram	11KV	Husnabad	08.50	11.20	02.30		DISK FAIL	
41	Siddipet	Nagapuri	Nagapuri	11KV	Husnabad	17.20	18.45	01.25		Jumper cutting	
42	Hyd South	Arundathi Colony	Habeeb Nagar	11KV	Asmanghad	14.33	16.05	01.32	EL	Tree branches & Foreign material fallen on lines at Habeeb Ngr	

S. No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
43	Hyd South	Laxmi Nagar	Dhobighat	11KV	Asmanghad	14.44	15.55	01.11	EL	No Visible Fault	
44	Hyd Central	Industrial Area	RTC X-Road	11KV	Azamabad	14.45	16.10	01.25	EL	Cable fault at Annapurna Bar & Restaurent	
45	Hyd South	Malakpet	Bibi Ka Alwa	11KV	Asmanghad	14.50	16.30	01.40	EL	Disc Insulator flash over at Pentaiah DTR	
46	Secundeerabad	Macha Bollarum	Ayyappa Nagar	11KV	Bowenpally	18.35	19.40	01.05	Opened AR	No Visible Fault	
47	Secundeerabad	Marredpally	Tagore Home	11KV	Bowenpally	19.10	20.21	01.11	EL	I/C Cable fault	
48	MEDCHAL	Nizampet	Rajadhani school	11KV	KUKATPALLY	00.20	02.05	01.45	EL/OL	11KV Pin Insulator failed & replaced at Bandari layout	
49	RAJENDRA NAGAR	IGHS	Shivaji nagar	11KV	RAJENDRA NAGAR	13.05	14.05	01.00	EL	Jumper cut & rebinded at Shivaji nagar Venture	
50	SAROOR NAGAR	Rajiv swagruha	Vishalandhra	11KV	SAROOR NAGAR	14.16	16.37	02.21	EL	Insulator failed & replaced at road no-4 Anand nagar	
51	SAROOR NAGAR	Madannapet	Durga bavani	11KV	CHAMPAPET	16.19	17.25	01.06	EL/OL	Tree fallen on line & removed at Yadagiri nagar	
52	MEDCHAL	Kompally	Aparna	11KV	MEDCHAL	18.38	19.50	01.12	EL/OL	Due to Heavy rain	
53	MEDCHAL	Pet bashirbad	St.Anns	11KV	MEDCHAL	18.35	20.00	01.25	EL	Tree fallen on line & removed at Police station and 11KV Pin insulator failed and rectified	
54	SAROOR NAGAR	Lenin nagar	Badangpet	11KV	CHAMPAPET	23.35	01.25	01.50	EL/OL	Lab Switch open at Badangpet, No Visible fault found	On 11KV Almasguda feeder from 33KV/11KV Almasguda SS
55	HABSIGUDA	Saket	Jawahar nagar	11KV	KEESARA	18.45	22.18	03.33	EL/OL	Due to rain, No visible fault found	On 11KV Santhosh nagar feeder from 33KV/11KV Balaji nagar SS