

Status Report on Breakdowns (Urban / Rural)

Urban

| S.No | Circle | No.of Feeders Existing Urban | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------|------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|-----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 18 | 107 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 2 | NLG | 22 | 358 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 3 | MDK | 97 | 359 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 4 | SDPT | | | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| 5 | RR(S) | 53 | 234 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 2 | |
| 6 | RR(N) | 54 | 550 | 0 | 2 | 0 | 2 | 0 | 2 | 0 | 2 | |
| 7 | RR(E) | 168 | 403 | 0 | 9 | 0 | 9 | 0 | 9 | 0 | 9 | |
| 8 | Hyd | 194 | 1044 | 0 | 5 | 0 | 5 | 0 | 5 | 0 | 5 | |
| | Total | 606 | 3055 | 0 | 18 | 0 | 18 | 0 | 18 | 0 | 18 | |

Rural

| S.No | Circle | No.of Feeders Existing Rurals | | Breakdowns occurred during the day | | Attended during the day | | Time taken for restoring the supply | | | | Remarks (Pending) |
|------|--------------------|-------------------------------|-------------|------------------------------------|-----------|-------------------------|-----------|-------------------------------------|-----------|--------------------------------|-----------|-------------------|
| | | 33KV | 11KV | 33KV | 11KV | 33KV | 11KV | Rectified (Within 24 Hours) | | Not Rectified (Above 24 Hours) | | |
| | | | | | | | | 33KV | 11KV | 33KV | 11KV | |
| 1 | MBN | 107 | 849 | 1 | 9 | 1 | 9 | 1 | 9 | 1 | 9 | |
| 2 | NLG | 144 | 988 | 1 | 3 | 1 | 3 | 1 | 3 | 1 | 3 | |
| 3 | MDK | 107 | 933 | 1 | 5 | 1 | 5 | 1 | 5 | 1 | 5 | |
| 4 | SDPT | | | 0 | 4 | 0 | 4 | 0 | 4 | 0 | 4 | 0 |
| 5 | RR(S) | 58 | 396 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 6 | RR(N) | 38 | 114 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| 7 | RR(E) | 22 | 133 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | |
| | Total | 476 | 3413 | 3 | 21 | 3 | 21 | 3 | 21 | 3 | 21 | |
| | Grand Total | 1082 | 6468 | 3 | 39 | 3 | 39 | 3 | 39 | 3 | 39 | |

TSSPDCL - LMRC / Corporate office**Circle-wise 33KV Breakdowns****Date: 05.09.2021**

| S.No | Circle | Name of 132/33KV SS | Name of 33 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Sub Stations Effected | Alternate Supply Arranged |
|------|------------|---------------------|----------------------|------|----------------------|-------|-------|----------|------------------|--|-----------------------|---------------------------|
| 1 | MBNR | Maddur | Kankurthy | 33KV | Narayanpet | 01.35 | 01.45 | 00.10 | EL&OL | No Visible fault due to Rain | | |
| 2 | Sangareddy | Zaheerabad | Hadnoor | 33KV | Zaheerabad | 01.07 | 03.00 | 01.53 | | BD due to Insulator failed | | |
| 3 | Yadadri | Choutuppal | Choutuppal | 33KV | Choutuppal | 11.06 | 13.06 | 02.00 | | Crow fallen at line at Markandiya venture Near Choutuppal town | | |

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 05.09.2021

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|-----------------|--------------------|------------------------|------|----------------------|-------|-------|----------|------------------|---|--|
| 1 | MEDCHAL | RGK Suraram | Kushi Colony | 11KV | JEEDIMETLA | 00.05 | 01.10 | 01.05 | EL | Disc Insulator failed and replaced at Govt School | |
| 2 | MEDCHAL | GP Pally | Dulapally | 11KV | Medchal | 08.15 | 09.50 | 01.35 | | 11KV Line cut and replaced at Forest Area,Dulapally | |
| 3 | Habsiguda | Cheralpally | Ramapally | 11KV | Keesara | 08.33 | 10.54 | 02.21 | | Pin insulator failed at Shastri Colony | |
| 4 | Habsiguda | Aushapur | Aushapur | 11KV | Keesara | 18.00 | 19.00 | 01.00 | | No falut found | |
| 5 | Habsiguda | NN Colony | Keesara | 11KV | Bavana Rushi | 01.04 | 02.46 | 01.42 | EL | Tree branches Fallen on lines at Brundavan Colony | |
| 6 | Habsiguda | Cherlapally-5 | Keesara | 11KV | Rampally | 08.33 | 10.54 | 02.21 | EL | Pin insulator failed & replaced at Shastri nagar colony | |
| 7 | Habsiguda | Cherlapally-5 | Keesara | 11KV | Rampally | 17.39 | 18.49 | 01.10 | EL | No visible fault | |
| 8 | Habsiguda | Saket | Keesara | 11KV | Jawahar nagar | 21.52 | 23.13 | 01.21 | EL | Due to Rain & LAB Switch Open at Rose Garden | on 11KV Santosh Nagar From 33KV Balaji Nagar |
| 9 | RAJENDRA NAGAR | Mamidipally | Pahadi Sharief | 11KV | KANDUKUR | 01.10 | 04.00 | 02.50 | EL | 11kv Pin Insulator Failed & Replaced at Ranganayakula Tanda | |
| 10 | CYBER CITY | CBIT | Gandipet | 11KV | IBRAHIMBAGH | 16.18 | 17.25 | 01.07 | EL | Insulator failed & replaced at Villa green | |
| 11 | SAROOR NAGAR | Nandanavanam | Janardhan reddy | 11KV | CHAMPAPET | 07.35 | 09.40 | 02.05 | EL/OL | LABS jumper cut & rebinded at Masjid | |
| 12 | SAROOR NAGAR | Almasguda | Nandhi hills | 11KV | CHAMPAPET | 23.20 | 01.20 | 02.00 | EL | 11kv Pin Insulator Failed & Replaced at Teachers Colony | |
| 13 | SAROOR NAGAR | Vanastalipuram | Hastinapuram | 11KV | CHAMPAPET | 23.55 | 01.53 | 01.58 | OL | HT Line Snapped at DRDL Colony | |
| 14 | Hyderabad North | Gymkhana | Sikh Village | 11KV | Bowenpally | 02.55 | 04.40 | 01.45 | EL,OL-R&Yph | Line snapped at Batiya Furniture | |
| 15 | Hyderabad North | Seethaphal Mandi | Srinivasa Nagar Colony | 11KV | Paradise | 11.50 | 13.00 | 01.10 | EL,OL-R&Yph | Construction material fallen on lines at Laxmi Apts | |
| 16 | Hyderabad North | Addagutta | Addagutta | 11KV | Paradise | 16.30 | 18.20 | 01.50 | EL | Pin Insulator flash over at Railway Track | |
| 17 | Hyderabad South | Falaknuma | Farooq Nagar | 11KV | Charminar | 15.50 | 17.20 | 01.30 | EL,OL | AB Cable fire catch at Patel Hotel | |
| 18 | Hyderabad South | Gunj | Gunj | 11KV | Asmangadh | 17.46 | 20.00 | 02.14 | EL,OL-Rph | DTR fault at BSNL Exchange | |
| 19 | MBNR | Kothamolgara | Kothamolgara | 11KV | Jadcherla | 01.10 | 10.55 | 09.45 | | BD 11KV Disk fail near Kappeta | |
| 20 | MBNR | Kothamolgara | Karvena | 11KV | Jadcherla | 01.05 | 07.05 | 06.00 | | BD 11KV Wire cut near Karvena | |

| S.No | Circle | Name of 33/11KV SS | Name of 11 KV Feeder | Vol | Name of the Division | From | To | Duration | Relay Indication | Cause of Breakdown | Alternate Supply Arranged |
|------|------------|--------------------|----------------------|------|----------------------|-------|-------|----------|------------------|---------------------------------------|---------------------------|
| 21 | MBNR | Kollur | Depally | 11KV | Jadcherla | 10.25 | 11.40 | 01.15 | | BD 11KV Insulator fail near Depally | |
| 22 | MBNR | Kollur | Kollur Town | 11KV | Jadcherla | 07.29 | 09.35 | 02.06 | | BD DTR Fail near Kollur Town | |
| 23 | MBNR | Janampet | 24 Hours | 11KV | Jadcherla | 00.00 | 06.30 | 06.30 | | BD 11KV Disk fail near Janampet | |
| 24 | MBNR | Annasagar | Annasagar Town | 11KV | Jadcherla | 00.00 | 07.40 | 07.40 | | BD 11KV Insulator fail near Annasagar | |
| 25 | MBNR | Marikal | Chakalapally | 11KV | Jadcherla | 01.48 | 07.55 | 06.07 | | BD 11KV Wire cut near Chakalapally | |
| 26 | MBNR | Nawabpet | Lokirew | 11KV | Jadcherla | 00.00 | 08.30 | 08.30 | | BD 11KV Insulator fail near Lokirew | |
| 27 | MBNR | Jadcherla | Burgupally | 11KV | Jadcherla | 06.20 | 11.40 | 05.20 | | BD 11KV Jumper cut near Aloor | |
| 28 | Nalgonda | B.Vellemla | B.Vellemla | 11KV | Nalgonda | 20.47 | 21.57 | 01.10 | E/L | 11 Kv Jumper Cutt | |
| 29 | Nalgonda | Chinthpally | Vinjamoor | 11KV | Devarakonda | 08.10 | 10.00 | 01.50 | E/L | Pin insulator Failed | |
| 30 | Nalgonda | K.M.Pally | C.A.Pally | 11KV | Devarakonda | 11.00 | 12.30 | 01.30 | E/L | Jumper Cut | |
| 31 | Siddipet | NACHARAM SS | NARSAMPALLY FEEDER | 11KV | Gajwel | 21.30 | 11.00 | 14.30 | | 11KV DISC FAILED | |
| 32 | Siddipet | KONDAPAKA SS | NACHARAM AGL FEEDER | 11KV | Gajwel | 11:25 | 14:25 | 3:00 | | LINE TRIPPING HEAVY RAIN | |
| 33 | Siddipet | HUSNABAD | POTLAPALLY | 11KV | HUSNABAD | 07.12 | 07.12 | 00.00 | | B.D, HEAVY RAIN | |
| 34 | Siddipet | Guruvannapet | Posanpally | 11KV | HUSNABAD | 03.36 | 04.48 | 01.12 | | B.D, HEAVY RAIN | |
| 35 | Sangareddy | Patancheru Town | Allwyn | 11KV | Patancheru | 14.50 | 16.50 | 02.00 | | BD due to Insulator failed | |
| 36 | Sangareddy | Patancheru Town | Shanthinagar | 11KV | Patancheru | 12.50 | 14.05 | 01.15 | | BD due to CT Jumper cut | |
| 37 | Sangareddy | Sangareddy Town-II | Kosla | 11KV | Sangareddy | 01.10 | 02.02 | 00.52 | | BD due to Conductor snapped | |
| 38 | Sangareddy | Sangareddy Rural | PR Pally Feeder | 11KV | Patancheru | 15.30 | 16.30 | 01.00 | | BD due to Insulator failed | |
| 39 | Sangareddy | Sangareddy Rural | PR Pally Feeder | 11KV | Patancheru | 17.03 | 18.01 | 00.58 | | BD due to Disk failed | |