

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	2	0	2	0	2	0	2	
6	RR(N)	54	550	0	7	0	7	0	7	0	7	
7	RR(E)	168	403	0	6	0	6	0	6	0	6	
8	Hyd	194	1044	0	5	0	5	0	5	0	5	
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>20</b>	<b>0</b>	<b>20</b>	<b>0</b>	<b>20</b>	<b>0</b>	<b>20</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	2	0	2	0	2	0	2	
2	NLG	144	988	0	4	0	4	0	4	0	4	
3	MDK	107	933	1	3	1	3	1	3	1	3	
4	SDPT			0	6	0	6	0	6	0	6	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	0	0	0	0	0	0	0	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>1</b>	<b>15</b>	<b>1</b>	<b>15</b>	<b>1</b>	<b>15</b>	<b>1</b>	<b>15</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>1</b>	<b>35</b>	<b>1</b>	<b>35</b>	<b>1</b>	<b>35</b>	<b>1</b>	<b>35</b>	

**TSSPDCL - LMRC / Corporate office**

**Circle-wise 33KV Breakdowns**

**Date: 06.09.2021**

<b>S.No</b>	<b>Circle</b>	<b>Name of 132/33KV SS</b>	<b>Name of 33 KV Feeder</b>	<b>Vol</b>	<b>Name of the Division</b>	<b>From</b>	<b>To</b>	<b>Duration</b>	<b>Relay Indication</b>	<b>Cause of Breakdown</b>	<b>Sub Stations Effected</b>	<b>Alternate Supply Arranged</b>
1	Sangareddy	Gummadidala	Gummadidala	33KV	Patancheru	02.05	06.35	04.30		BD due to Conductor snapped & Insulator failed		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 06.09.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Habsiguda	Sainikpuri	Saipuri	11KV		17.45	19.00	01.15		11Kv Polimer Disk failed at GK Classic Apport. Hasthinapuri Colony (AE/OP)	
2	Habsiguda	Moula-Ali	Malkajiri	11KV		17.10	18.10	01.00		Kite fallen on 11Kv line at Hanuman Nagar RTC Colony (AE/OP)	
3	Habsiguda	Saket	Jawahar nagar	11KV	KEESARA	10.40	12.04	01.24	EL	No Visible Fault	
4	Mahaboobnagar	Kothamolgara	Kothamolgara	11KV	Jadcherla	11.25	13.34	02.09		11KV Insulator fail near Kappeta(V)	
5	Mahaboobnagar	Konded	Chinna Adirala	11KV	Jadcherla	08.30	12.30	04.00		11KV Insulator fail near Chinna Adirala Kuntla	
6	Medchal	D P PALLY	AGL Gagillapur	11KV	Jeedimetla	08.00	15.10	07.10	EL/OL	Jumper cutting and fall on DTR at Nagloor cheruvu katta	
7	Medchal	Gagillapur	EXCEL	11KV	Jeedimetla	15.00	16.00	01.00	OL	Tree fall on 11kv line at Chaitanya colony Gagillapur	
8	Medchal	UMCC	Mini Industry	11KV	MEDCHAL	21.55	23.15	01.20		11Kv AB Cable failed at CMR School Gajularamaram (Backfe feting )	
9	Medchal	UMCC	Mahadevpuram	11KV	MEDCHAL	16.50	17.15	00.25		AB Cable Sparked at Ushodaya Colony, Main Road & Loads are diverted to 11KV Crusher feeder	
10	Medchal	Medchal	Check Post	11KV	MEDCHAL	03.00	04.30	01.30		11KV Disc failed at Masjid Backside	
11	Medchal	Kistapur	IDA Hanuman	11KV	MEDCHAL	07.05	09.25	02.20		11KV Line Cut & Replaced at Rudra Prathap Company	
12	Medchal	Ushamullapudi	Mini Industry	11KV	MEDCHAL	21.55	23.25	01.30	EL	AB cable failed & isolated at CMR school	
13	Nalgonda	Kethepally	Kasangodu	11KV	Nalgonda	01.00	04.15	03.15	EL	Insulator Failed	
14	Nalgonda	K.M.Pally	11KV K.M.PALLY Industrial Feeder	11KV	Devarakonda	10.30	12.10	01.40	EL	Conductor Snapped	
15	Nalgonda	Padamatipally	11 KV Iddampally Feeder	11KV	Devarakonda	07.10	08.30	01.20	EL	Pin insulator failed	
16	Siddipet	Mallaram	Sikndulapur	11KV	Siddipet	15.31	18.26	02.55		B/D EL Tripping	
17	Siddipet	THUKKAPUR SS	INDUSTRIAL FEEDR	11KV	Gajwel	01.10	16.30	15.20		LORRY ACCIDENT 4POLES DAMAGE	
18	Siddipet	DHARMARAM	Nandaram	11KV	Husnabad	17.11	19.38	02.27		INSULATOR FAIL	
19	Siddipet	MUSTYALA	CHUNCHANAKOTA	11KV	Husnabad	17.15	19.35	02.20		JUMPER CUT	
20	Siddipet	GAGILLAPUR	NARSAIPALLY	11KV	Husnabad	15.02	15.17	00.15		BREAK DOWN	

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
21	Siddipet	AKKANAPET	FAKKIRNAYAK THANDA	11KV	Husnabad	19.10	20.10	01.00		INSULATOR FAIL	
22	Sangareddy	Sangareddy Town-II	Filterbed	11KV	Sangareddy	06.05	08.45	02.40		BD due to Tree fallen on line	
23	Sangareddy	Sangareddy Town-II	Filterbed	11KV	Sangareddy	18.13	20.52	02.39		BD due to Insulator replaced	
24	Sangareddy	Bollaram - I	Soubagya	11KV	Patancheru	21.30	22.40	01.10		BD due to Jumper cur	
25	Suryapet	Palakeedu	Nagireddy gudem	11KV	Huzurnagar	05.00	07.45	02.45		11 KV LINE SNAPPED	
26	Secunderabad	Hyderguda	Boggula Kunta	11KV	Saifabad	06.20	07.25	01.05	All Indication	3Way RMU fault at Ahuja Estate	
27	Secunderabad	Bowenpally	Kalinga Enclave	11KV	Bowenpally	17.00	18.40	01.40	OL	No Visible Fault (Due to Rain)	
28	Secunderabad	Chilkaiguda	Dandu Pentaiah	11KV	Paradise	19.55	21.12	01.17	EL,OL	HT Jumper cut at Gandhi Hospital Main Gate	
29	Secunderabad	Chilkaiguda	New Boiguda	11KV	Paradise	19.55	22.00	02.05	EL,OL	R.M.U UG Cable at Opp: DE/Office, P.R Nagar	
30	Secunderabad	Chilkaiguda	Pragatools	11KV	Paradise	21.10	22.54	01.44	OL-R,Y&Bph	I/C Cable Jumper cut at Mohammadia Mansion	
31	CYBER CITY	Vattinagulapally	Aparna	11KV	IBRAHIMBAGH	00.32	03.32	03.00	EL/OL	Due to rain & Line patrolling done no visible fault	
32	CYBER CITY	Vattinagulapally	Aparna	11KV	IBRAHIMBAGH	22.30	02.02	03.32	EL/OL	11KV Pin insulator failed & replaced at ORR	
33	RAJENDRA NAGAR	ICAR	Naram	11KV	RAJENDRA NAGAR	01.12	06.10	04.58	EL	11Kv Disc failed & replaced at Naram gate	
34	SAROOR NAGAR	Vanasthalipuram	Hashtinapuram	11KV	CHAMPAPET	02.15	03.43	01.28	OL	11Kv Disc failed & replaced at Venkateshwara colony	
35	RAJENDRA NAGAR	ICAR	Rajendra Nagar	11KV	RAJENDRA NAGAR	19.13	23.10	03.57	EL	ABS open at MRO office(1DTR kept off)	