

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	5	0	5	0	5	0	0	
6	RR(N)	54	550	1	7	1	7	1	7	0	0	
7	RR(E)	168	403	0	9	0	9	0	9	0	0	
8	Hyd	194	1044	0	2	0	2	0	2	0	0	
	Total	606	3055	1	23	1	23	1	23	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	0	0	0	0	0	0	0	
2	NLG	144	988	3	7	3	7	3	7	0	0	
3	MDK	107	933	3	7	3	7	3	7	0	0	
4	SDPT			3	17	3	17	3	17	0	0	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	0	0	0	0	0	0	0	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	Total	476	3413	9	31	9	31	9	31	0	0	
	Grand Total	1082	6468	10	54	10	54	10	54	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 33KV Breakdowns

Date: 07.09.2021

S.No	Circle	Name of 132/33KV SS	Name of 33 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Sub Stations Effected	Alternate Supply Arranged
1	Medchal	132KV LGM Pet	33KV LGM Pet	33KV	Medchal	16.35	20.00	03.25		33 KV Line Cut at 33KV Monasanto India, LGM Pet (V)		
2	Nalgonda	220KV Miryalaguda	Tripuraram	33KV	Miryalaguda	14.07	16.10	02.03	EL	33KV Jumper Cut Fallen On Stay Clamp		
3	Suryapet	Suryapet	P V C	33KV	Suryapet	06.30	08.45	02.15		Jumper cut		
4	Yadadri	Bibinagar	MLR	33KV	Bhongir	08.24	10.15	01.51		2 Crows fallen at line & R-Phase CT jumper snapped in 132 kv Yard		
5	Sangareddy	Jogipet	G.Peddapur		Jogipet	07.40	09.55	02.15		B/D Due to tree Branch fallen on the line		
6	Sangareddy	Zaheerabad	Phiramil		Zaheerabad	07.10	11.30	04.20		B/D Due to Jumper Cut		
7	Sangareddy	Pashamailaram	Nactor		Sangreddy	05.30	18.40	13.10		B/D Due to 33KV Breaker limb failure		
8	Siddipet	Gajwel	Mulugu		Gajwel	03.20	09.30	06.10	BD LA Balast	BD(2 Insulators disk replacement)		

Date: 07.09.2021

9	Siddipet	Thukkapur	Lingapur		Gajwel	13.55	15.15	01.20		BD(Y-phase Lightng arrester blast)		
10	Siddipet	Shanigaram	Bejjanki		Husnabad	01.20	07.40	06.20		BD(Tree branches fell on the line)		

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 07.09.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Medchal	J T PL	P N R Hills	11 KV	Kukatpally	04.05	05.45	01.40	EL/OL	11kv Pin Insultor Failure At R T c Colony	
2	Medchal	Aleap	Pragathinagar	11 KV	Jeedimetla	01.28	04.05	02.37	EL/OL	11kv Pin Insultor Failure At pragathinagar	
3	Medchal	DP Pally -II	Indo-Feb	11 KV	Jeedimetla	09.55	11.50	01.55	EL/OL	11kv Disk Failure At Gayathri Nagar	
4	Medchal	Thurkapally	Yadaram	11 KV	MEDCHAL	03.30	07.35	04.05		2Nos 11KV Pin Insulators Failed at Prajay Enclave,Murarpalli	
5	Medchal	Town Medchal	Jyothi Nagar	11 KV	MEDCHAL	04.10	06.00	01.50		11KV Jumper cut and replaced at Fish Market	
6	Medchal	Devarayamjal	Pothaipally	11 KV	MEDCHAL	05.50	08.30	02.40		Tree Fallen on 11KV Line at Pandu Reddy Godham,Yamjal	
7	Medchal	Kandlakoya	KV Reddy Nagar	11 KV	MEDCHAL	06.20	07.45	01.25		Tree Fallen on 11KV Line at Modi Xerox	
8	Nalgonda	Nakrekal	Market	11 KV	Nalgonda	00.05	01.13	01.08	EL	Insulator Failed	
9	Nalgonda	Narsingbatla	Kuthuru Gudem	11 KV	Nalgonda	02.50	08.05	05.15	EL	11 kv Jumper Cutt	
10	Nalgonda	Kattangur	Mallaram	11 KV	Nalgonda	02.00	07.30	05.30	EL	11 KV Disc Probleam	
11	Suryapet	B N L Thanda	patha thanda	11 KV	Huzurnagar	00.20	07.20	06.00		11 KV LINE SNAPPED	
12	Suryapet	REPALA	REPALA	11 KV	Huzurnagar	05.50	07.30	01.40		11 KV JUMPER CUT	
13	Yadadri	Choutuppal ipds	Lakkaram	11 KV	Choutuppal	00.04	02.24	02.20		02 no'S 11 KV Poles & 01 no LT Pole dammages in Lorry accident near Lakkaram village. Division office in side	
14	Yadadri	Golnepally	Express Indl	11 KV	Choutuppal	08.39	13.22	04.43		CT PT Failed at JV farams company	
15	Hyd (South)	Malakpet	Bibi Ka Alwa	11 KV	Asmanghad	02.20	03.35	01.15	EL,OL-Rph	Post type Insulator flash over at Farhath Nagar Nala	
16	Hyd (Central)	Industrial Area	Azamabad Key SS	11 KV	Mehdipatnam	05.05	06.16	01.11	EL	No Visible Fault	
17	Sangareddy	EPIP-III	Ufoam	11 KV	Sangareddy	10.05	11.10	01.05	B/D Due to Jumper Cut		
18	Sangareddy	EPIP-III	Vilas Polymer	11 KV	Sangareddy	10.20	11.20	01.00	B/D Due to Conductor Snapped		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
19	Sangareddy	EPIP-I	kirby	11 KV	Sangareddy	05.45	09.20	03.35	B/D Due to Conductor Snapped		
20	Sangareddy	EPIP-I	Chaitanya	11 KV	Sangareddy	09.15	11.20	02.05	B/D Due to Conductor Snapped		
21	Sangareddy	Hathnoora	Town Indl.	11 KV	Patancheru	09.47	10.30	00.43	B/D Due to tree Branch fallen on the line		
22	Sangareddy	EPIP-II	Srinivasa Costing	11 KV	Sangareddy	02.40	08.05	05.25	B/D Due to tree Branch fallen on the line		
23	Sangareddy	Patancheru Town	Shanthinagar	11 KV	Patancheru	05.10	05.50	00.40	B/D Due to Jumper Cut		
24	Siddipet	Dubbak IPDS	Gandhi feeder		Siddipet	09.56	10.35	00.39	B/D Disk fail		
25	Siddipet	Laxmidevipally	Ibrahimpur		Siddipet	09.00	13.10	04.10	B/D Disk fail & LC.No.19131		
26	Siddipet	Jangapally	Jangapally		Siddipet	00.00	12.00	12.00	Bross patti cut &		
27	Siddipet	Mirdoddy	Kasulabad		Siddipet	07.30	14.20	06.50	B/D Jumper cut		
28	Siddipet	Peddakodur	Chinnakodur		Siddipet	08.00	14.00	06.00	branch fall on the line &		
29	Siddipet	ERRAVALLY	ERRAVALLY TOWN		Gajwel	12.25	13.00	00.35	DISC FAILED		
30	Siddipet	PAMULAPARTHY	INDHRANAGAR		Gajwel	15.20	15.45	00.25	DISC FAILED		
31	Siddipet	GAJWEL	TOWN-1		Gajwel	01.03	08.37	07.34	2NOs DISC FAILED		
32	Siddipet	MEDHINIPUR	MANGOLE		Gajwel	08.15	12.40	04.25	DISC FAILED		
33	Siddipet	MEDHINIPUR	KUKUNOORPALLY		Gajwel	09.00	11.00	02.00	DISC FAILED		
34	Siddipet	HUSNABAD (IPDS)	Husnabad Town-IV		Husnabad	00.00	01.20	01.20	Disc failed		
35	Siddipet	PANDILLA	PANDILLA EXPRESS		Husnabad	04.10	08.30	04.20	Tree fell on line		
36	Siddipet	Cherial	Rollabanda Agl		Husnabad	01.00	08.00	07.00	insulator failed		
37	Siddipet	Mustyal	Cherial Town		Husnabad	05.55	08.50	02.55	jumper open		
38	Siddipet	Mustyal	Cherial Town		Husnabad	11.05	12.00	00.55	Tree branches open		

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
39	Siddipet	Nagapuri	Nagapuri		Husnabad	08.50	10.50	02.00	Disc failed		
40	Siddipet	Bekkal	Bekkal 24hrs		Husnabad	00.00	09.00	09.00	insulator failed		
41	SAROOR NAGAR	Vanastalipuram	Ngo's Colony		CHAMPAPET	00.05	01.14	01.09	EL	Tree Branch Fallen on Line and removed at Ngo's Colony	
42	SAROOR NAGAR	Lenin Nagar	Dathu Nagar		CHAMPAPET	03.40	05.50	02.10	EL/OL	Due to Rain & 11KV Disc Failed and replaced at Midani	
43	SAROOR NAGAR	Maruthi Nagar	Vasavi Colony		SAROOR NAGAR	02.16	07.04	04.48	EL	Pin Insulator failed and rectified at Vasavi colony	
44	SAROOR NAGAR	RR Court	Haripuri colony		SAROOR NAGAR	09.55	13.19	03.24	OL	11kv Insulator Failed & Replaced at Telangana Fuction hall	
45	Habsiguda	Yapral	Tulasi Garden	11 KV	Sainikpuri	03.30	04.30	01.00		Ground petrolling done but no visible fault found (due to AB Switch Open at Shaili Garden)	
46	Habsiguda	AS Rao Nagar	Majid	11 KV	Sainikpuri	05.26	06.34	01.08		11Kv line Phase-II to Phase line touching at Maruthi Enclave (AE/OP)	
47	Habsiguda	Cheralapally	Ramapally	11 KV	Keesara	03.02	03.55	00.53		Tripped EL (Havey rain)	
48	Habsiguda	CRPF	CRPF Non Residencial	11 KV	Keesara	03.30	10.35	07.05		CTPT Smoke & cable damaged in SS Yard	
49	Habsiguda	Aushapur	NFC Nagar	11 KV	Keesara	15.25	16.50	01.25		Pin Insulator failed at BT bus Stop	
50	RAJENDRA NAGAR	Gaganpahad	Silicon Rubber		RAJENDRA NAGAR	05.10	06.16	01.06	OL	11KV Disc failed and rectified at Pavan Industry	
51	RAJENDRA NAGAR	MD Pally	MD Pally (V)		RAJENDRA NAGAR	10.35	11.54	01.19	EL/OL	Raghavendra Hospiral and 11KV Line twisted at Mehfil Hotel, Jumper cut & rebinded near SS &	
52	RAJENDRA NAGAR	NPA	Sai Baba Nagar		RAJENDRA NAGAR	19.50	20.55	01.05	ELOL	Lug Cut & replaced at Railway Kaman	
53	CYBER CITY	Mathrusri nagar	Kalyan Garden		GACHIBOWLI	07.40	08.45	01.05	EL/OL	Pin Insulator failed and rectified at Vijetha Super Market	
54	CYBER CITY	Ibrahimbagh	Vasavi		IBRAHIMBAGH	15.36	16.37	01.01	EL	Tree Branch Fallen on 11KV Line and removed at Ibrahimbagh Bus stop	