

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	0	0	0	0	0	0	0	
6	RR(N)	54	550	0	0	0	0	0	0	0	0	
7	RR(E)	168	403	0	2	0	2	0	2	0	0	
8	Hyd	194	1044	0	2	0	2	0	2	0	0	
	Total	606	3055	0	4	0	4	0	4	0	0	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	2	0	2	0	2	0	0	
2	NLG	144	988	0	3	0	3	0	3	0	0	
3	MDK	107	933	0	1	0	1	0	1	0	0	
4	SDPT			0	6	0	6	0	6	0	0	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	0	0	0	0	0	0	0	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	Total	476	3413	0	12	0	12	0	12	0	0	
	Grand Total	1082	6468	0	16	0	16	0	16	0	0	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 14.09.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Habsiguda	Uppal	RTA	11KV	Habsiguda	16.58	18.00	01.02		11KV Line Snappen and Replased at Kendrya Vidyalayam	
2	Mahaboobnaga	Bhoothpur	Bhoothpur Rural	11KV	Jadcherla	08.06	09.31	01.25		11KV Phase To Phase Near Narsingapur (V)	
3	Mahaboobnaga	SARJAKANPET	TOGAPOOR	11KV	Narayanpet	06.40	08.00	01.20		Breakdown due to rain & wind	
4	Nalgonda	Kattanguru	Bollepally	11KV	Nalgonda	06.00	09.00	03.00	EL	11KV Line Jumper Cut	
5	Siddipet	Rampur	Rampur	11KV	Siddipet	5:15	15:00	9:45		B/D 11 KV line problem PTR 1 Problem	
6	Siddipet	Chowdaram	Chinna Kodur	11KV	Siddipet	13:31	18:02	4:31		B/D	
7	Siddipet	Gajwel-Pregnapur	Town II	11KV	Gajwel	7:13	8:08	0:55		Insulator Fail	
8	Siddipet	Nemtoor SS	Nemtoor	11KV	Gajwel	17:00	17:55	0:55		Bird Fallen on Line	
9	Siddipet	HUSNABAD	HUSNABAD TOWN-2	11KV	Husnabad	13.05	13.30	0.25		B.D, DUE TO LINE CUT	
10	Siddipet	GOURAVELLY	GUDATIPALLY	11KV	Husnabad	18.30	19.10	0.40		B.D, DUE TO BIRD FALLEN ON LINE	
11	Sangareddy	Isnapur	IDA Isnapur	11KV	Sangareddy	15.30	16.35	01.05		BD Due to Tree Branches Fallen on line	
12	Suryapet	Palakeedu	Sajjapuram	11KV	Huzurnagar	05.30	07.30	02.00		11 KV LINE SNAPPED	
13	Suryapet	Akupamula	Kodandarampuram	11KV	Huzurnagar	08.25	10.30	02.05		11 KV LINE SNAPPED	
14	Hyderabad sout	Santosh Nagar	Edi Bazar	11KV	Asmanghad	10.30	12.10	01.40	All Indication	3No. Jumpers cut & Line snapped at SS beside	
15	Hyderabad sout	Santosh Nagar	Jyothi Bagh	11KV	Asmanghad	10.30	12.10	01.40	All Indication	3No. Jumpers cut & Line snapped at SS beside	
16	RAJENDRA NAGAR	Indiragandhi Housing Sc	Payal Food	11KV	RAJENDRA NAGAR	20.01	21.11	01.10	ELOL	Line Patrolling Done, No Visible Fault & Due to Rain	