

**Status Report on Breakdowns (Urban / Rural)****Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	0	0	0	0	0	0	0	
6	RR(N)	54	550	0	0	0	0	0	0	0	0	
7	RR(E)	168	403	0	1	0	1	0	1	0	1	
8	Hyd	194	1044	0	2	0	2	0	2	0	2	
	<b>Total</b>	<b>606</b>	<b>3055</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	<b>0</b>	<b>3</b>	

**Rural**

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	1	0	1	0	1	0	1	
2	NLG	144	988	0	0	0	0	0	0	0	0	
3	MDK	107	933	0	0	0	0	0	0	0	0	
4	SDPT			0	6	0	6	0	6	0	6	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	0	0	0	0	0	0	0	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	<b>Total</b>	<b>476</b>	<b>3413</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	<b>0</b>	<b>7</b>	
	<b>Grand Total</b>	<b>1082</b>	<b>6468</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	<b>0</b>	<b>10</b>	



**TSSPDCL - LMRC / Corporate office**  
**Circle-wise 11KV Breakdowns**

**Date: 15.09.2021**

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	MBNR	Vemula	Maisigundlapally	11KV	Jadcherla	03.15	09.20	06.05		11KV Line Cut Near Edulabai Thanda Side	
2	Siddipet	AHAMADIPUR SS	KOLGUR AGL FEEDER (LC NO: 19426) RAMASWAMY JLM	11KV	Gajwel.	16.30	17.55	01.25		HT/LT	
3	Siddipet	THUNKIKHALSA SS	AMBARPET FEEDER (LC.NO.12335) RAMESH ARTISAN	11KV	Gajwel.	08.05	08.35	00.30		INSULATOR FAILED	
4	Siddipet	MULUGU SS	NARSAMPALLY FEEDER (LC.NO.12749)DHANPAL REDDY ALM	11KV	Gajwel.	09.40	10.50	01.10		11KV LINE CUT	
5	Siddipet	GURRALASOFA SS	VADDEPALLY VILAGE FEEDER(LC.NO: 4552) BHUPAL REDDY CI	11KV	Gajwel.	13:25	16:45	3:20		JUMPER CUT	
6	Siddipet	DHARMARAM	THIMMAIPALLY	11KV	Husnabad	12:40	15:45	3:05		INSULATOR FAIL	
7	Siddipet	ARJUNPATLA	KAMALAI PALLY	11KV	Husnabad	2:40	9:45	7:05		LINE CUT	
8	Saroornagar	Bandlaguda	Vambey colony	11KV	SAROOR NAGAR	5:20	7:20	2:00	EL/OL	UG Cable fault in Yard	11KV V-Guard
9	Hyd-central	Hussain Sagar	Meera Theatre	11KV	Saifabad	0.65	0.71	0.06	EL,OL	Cable Fault	Arranged B/F on 11KV Khairathabad feeder
10	Banjarahills	Kalyan Nagar	Rahamath Nagar	11KV	Banjarahills	0.79	0.85	0.06	EL,OL-Rph	AB Cable fault at Kallu Compound	Arranged B/F on 11KV Krishna Nagar feeder