

Status Report on Breakdowns (Urban / Rural)**Urban**

S.No	Circle	No.of Feeders Existing Urban		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	18	107	0	0	0	0	0	0	0	0	
2	NLG	22	358	0	0	0	0	0	0	0	0	
3	MDK	97	359	0	0	0	0	0	0	0	0	
4	SDPT			0	0	0	0	0	0	0	0	0
5	RR(S)	53	234	0	0	0	0	0	0	0	0	
6	RR(N)	54	550	0	0	0	0	0	0	0	0	
7	RR(E)	168	403	0	0	0	0	0	0	0	0	
8	Hyd	194	1044	0	1	0	1	0	1	0	1	
	Total	606	3055	0	1	0	1	0	1	0	1	

Rural

S.No	Circle	No.of Feeders Existing Rurals		Breakdowns occurred during the day		Attended during the day		Time taken for restoring the supply				Remarks (Pending)
		33KV	11KV	33KV	11KV	33KV	11KV	Rectified (Within 24 Hours)		Not Rectified (Above 24 Hours)		
								33KV	11KV	33KV	11KV	
1	MBN	107	849	0	0	0	0	0	0	0	0	
2	NLG	144	988	0	1	0	1	0	1	0	1	
3	MDK	107	933	0	1	0	1	0	1	0	1	
4	SDPT			0	2	0	2	0	2	0	2	0
5	RR(S)	58	396	0	0	0	0	0	0	0	0	
6	RR(N)	38	114	0	1	0	1	0	1	0	1	
7	RR(E)	22	133	0	0	0	0	0	0	0	0	
	Total	476	3413	0	5	0	5	0	5	0	5	
	Grand Total	1082	6468	0	6	0	6	0	6	0	6	

TSSPDCL - LMRC / Corporate office

Circle-wise 11KV Breakdowns

Date: 17.09.2021

S.No	Circle	Name of 33/11KV SS	Name of 11 KV Feeder	Vol	Name of the Division	From	To	Duration	Relay Indication	Cause of Breakdown	Alternate Supply Arranged
1	Medchal	UMCC	Mahadevpuram	11KV	Medchal	0.42	0.48	1:30		AB Cable damaged at Gajularamaram Chowrasta(40% Load added to 11KV Gajularamaram feeder)	
2	Siddipet	LINGAPUR SS	VENKATRAOPET FEEDER (LC.NO.13800) RAJESHAM LM	11KV	Gajwel	9:20	13:15	4:15		INSULATOR FAILED	
3	Siddipet	Potharam	Nagaram	11KV	Husnabad	06.25	06.45	00.20		Tree Branch Fallen on the line	
4	Sangareddy	Gummadidala	Bell Remedies	11KV	Patancheru	00.55	05.50	04.55		BD due to Jumper cut	
5	Suryapet	Janpahad	Janpahad	11KV	Huzurnagar	7:00	8:45	1:45		11 KV LINE SNAPPED	
6	Sec-bad	Chinthal	Caption Gas	11KV	Bowenpally	11:30	14:15	2:45	EL,OL	Cable End Kit fault & Breaker fault at SS	Arranged B/F on 11KV L&T feeder