



SOUTHERN POWER DISTRIBUTION COMPANY OF TELANGANA LIMITED

6-1-50, Corporate Office, Mint Compound, Hyderabad - 63

Supply, Installation, Testing and Commissioning of Hardware & Software for RT-DAS for measurement of SAIFI/SAIDI in all substations of 34 No.s non SCADA town of R-APDRP and IPDS

Corrigendum -2

Sl.No.	Existing Clause		Amended as
1	Bid Guarantee	2% of ECV i.e. Rs.6,40,000/-	Bid Guarantee to be submitted for 2% of ECV+18% GST i.e. Rs. 7,55,200/-
2	Performance Bank Guarantee	10% of contract value	Performance Bank Guarantee to be submitted for 10% of contract value+18% GST
3	Clarification on labour cess		The Labour Cess under Telangana Building and Other Construction Workers Welfare Cess Act 1996 and Cess Rules 1998 will be recovered @1% on total bill amount (i.e. on material and labour amount) from the contractor.
4	AC distribution boards shall be provided for UPS input and output power distribution. The distribution boards shall distribute power and provide protection against failures on feeder circuits, to the equipment.		Every substation is provided with ACDB. 3 phase/1 phase supply can be availed from existing ACDB for 24V DCPS.
5	The number of SMPS modules to be provided in the DCPS system shall be provided in N+2 configuration.		N+1 configuration of SMPS is sufficient for functioning of DCPS.

Sd/-
Chief General Manager/Projects
TSSPDCL