



SOUTHERN POWER DISTRIBUTION COMPANY OF TELANGANA LIMITED

6-1-50, Corporate Office, Mint Compound, Hyderabad - 63

Supply, Installation, Testing and Commissioning of Hardware & Software for RT-DAS for measurement of SAIFI/SAIDI in all substations of 34 No.s non SCADA town of R-APDRP and IPDS

Corrigendum -3

Sl.No.	Existing Clause	Amended as
1	The FRTU will be powered from a 48V DC power supply system	Standard DC power supply such as 24 V DCPS, 3 Amp, 20AH, SMF/VRLA Batteries shall be considered
2	Under Communication Establishment of page 42 :	Clarification : At Data center - MPLS (FO link) is mandatory. At field FRTUs - 4G Modem with VPN is required with uptime availability of 98%.

Sd/-
Chief General Manager/Projects
TSSPDCL